tyco SimplexGrinnell

20 Thomas
WESTBRO(
(207) 842 6
FAX: (207) 8
www.simple

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions

# SimplexGrinnell Material List (THIS IS NOT A PRICE QUOTAT

Date: 07/31/13

TO:
Somma Electric
16 Marie St
GRAY, ME 04039-9755
Attn: Joseph Somma
(207) 632-3485 EXT(____) Fax:

Project: Cathedral Residence 4010es PHASE 1
Customer Reference:
SimplexGrinnell Reference: 147422230
Date: 02/08/2013
Page 1 of 2

| QUANTITY | MODEL NUMBER | DESCRIPTION |
|---|---|---|
| | **Cathedral Residence 4010es** | |
| | Cathedral Residence 4010es | |
| 1 | 4010-9402 | 4010ES FACP 120V PLATINUM |
| 1 | 4010-9912 | SERIAL DACT |
| 2 | 2081-9288 | BATTERY 12.7AH |
| 1 | SSU00672 | CAB DOC STORAGE 12X13X2D RED |
| 5 | 4099-9003 | MANUAL STATION - DOUBLE ACTION |
| 20 | 4098-9714 | PHOTO SENSOR |
| 23 | 4098-9792 | SENSOR BASE |
| 3 | 4098-9733 | HEAT SENSOR |
| 5 | 4906-9129 | HORN/STROBE MC WHITE |
| 3 | 4090-9002 | RELAY IAM |
| 1 | ETHEDROP | ETHERNET-NETWORK COMPATIBLE |
| 1 | DPSVC | DP SVCS (PERMITS/FEES/BONDS) |
| | Professional Services - Cathedral Residence 4010es | |
| 4 | PM LAB | PROJECT/CONSTRUCTION MGMT |
| | Technical Services - Cathedral Residence 4010es | |
| 16 | TECH LAB | TECHNICAL SERVICE |

Comments

This quote includes the following:

1. A Simplex 4010es Addressable Panel.
2. Addressable replacements for the existing conventional devices.
3. Replacement ADA Compliant Horn-Strobes.
4. A Digital Communicator.
5. Programming and Testing.
6. A Fire Alarm Permit from the Portland Fire Dept.

This quote does not include any additional devices. If additional devices are required it would be at an additional cost.

This quote does not include Monitoring.

This quote is subject to the approval of the Portland Fire Dept.

This quote is valid for 30 days.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/31/13

## SimplexGrinnell Material List (THIS IS NOT A PRICE QUOTAT

Comments (continued)