20 Thomas
WESTBRO
(207) 842 64
FAX: (207) 8
www.simple

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

SimplexGrinnell Material List (THIS IS NOT A PRICE QUOTAT

Date: 07/15/13

TO:
Cathedral Residence
307 CONGRESS ST
PORTLAND, ME 04101
Attn: Jim Somma
(207) 773-6471 EXT(____) Fax:

Project: Cathedral Residence 2 Phase 2
Customer Reference: Cathedral Residence 2
SimplexGrinnell Reference: 147422230
Date: 02/08/2013
Page 1 of 1

QUANTITY	MODEL NUMBER	DESCRIPTION
	Cathedral Residence 2	
	Cathedral Residence 2	
12	4906-9103	STROBE MC WHITE
13	4906-9129	HORN/STROBE MC WHITE
5	4099-9003	MANUAL STATION - DOUBLE ACTION
3	2975-9178	BACKBOX MANUAL STATION
1	4009-9201	NAC EXTENDER 120VAC, IDNET
2	2081-9274	BATTERY 10AH
1	4906-9105	WP VO MC NON-ADDR WALL RED
1	4905-9828	WP AV/VO 1.5IN BACK BOX RED
1	DPSVC	DP SVCS (PERMITS/FEES/BONDS)
	Technical Services - Cathedral Residence 2	
20	TECH LAB	TECHNICAL SERVICE
	Professional Services - Cathedral Residence 2	
4	PM LAB	PROJECT/CONSTRUCTION MGMT

Comments

This quote is for budgetary purposes only and is subject to the approval of the Portland Fire Department.

This quote would include Programming and Testing.
This quote would not include wiring or installation.