

1' LAYER OF INSULATION
FACTORY INSTALLED IN
1.00' END STANDOFF MEETS
0" REQUIREMENTS CLEARANCE
TO COMBUSTIBLE SURFACES.

INSTALLER MUST CONFIRM HOOD IS INSTALLED SUCH THAT THE SPECIFIED WALL, ACTING AS AN END PANEL, IS MATED TIGHT TO THE CORRECT END OF HOOD TO ACHIEVE A REDUCED MINIMUM EXHAUST CFM LISTING. NON-COMPLIANCE WILL NULLIFY THE ETL LISTING, VOID THE MANUFACTURER'S WARRANTY, AND HOLD THE CONTRACTOR LIABLE FOR ANY AND ALL LOSSES, COSTS, AND EXPENSES RELATED TO THE NON-COMFORMANCE OF THE MANUFACTURER'S SPECIFIED INSTRUCTION. THE WALL ACTING AS AN END PANEL MUST EXTEND NO LESS THAN 20" FROM THE INTERSECTING WALL ON WHICH HOOD IS MOUNTED AND MUST EXTEND NO LESS THAN 20" UNDER BOTTOM OF HOOD TO BE ELIGIBLE FOR REDUCED MINIMUM EXHAUST CFM LISTING.

PLAN VIEW - Hood #1 (LEFT)
8' 0.00" LONG 5412SND-2

PLAN VIEW - Hood #2 (RIGHT)
8' 0.00" LONG 5412SND-2

PLAN VIEW - Hood #3 (LEFT HOOD SUPPLY) VIEW - Hood #4 (RIGHT HOOD SUPPLY)
8' 0.00" LONG 266MISC-PSP 8' 1.00" LONG 266MISC-PSP

CUSTOMER APPROVAL TO MANUFACTURE:


Approved as noted

Approved with NO Exception Taken

Revised and Resubmit

SIGNATURE _____

Your Title _____ Date _____



JOB Uncle Billy BBQ r1	
LOCATION POLAND, ME,	
DATE 8/21/2017	JOB # 3121910
DWG # 2	DRAWN BY BFC-21
REV.	SCALE 3/8" = 1'-0"