

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716


Permit No: 09-0467	Issue Date: 6/12/09	CBL: 021 E009001
-----------------------	------------------------	---------------------

Location of Construction: 160 CUMBERLAND AVE	Owner Name: KONTOS CAROL & GREGORY C	Owner Address: PO BOX 1785	Phone:
Business Name:	Contractor Name: Charlie Burnham Heating	Contractor Address: PO Box 382 Freeport	Phone: 2078659010
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: R-6

Past Use: Multi-Family	Proposed Use: Multi-Family - Install a System 2000 Frontier Boilers Energy Kinetics Boiler	Permit Fee: \$160.00	Cost of Work: \$13,150.00	CEO District: 1
<p><i>Copy of D.U. - 6/12/09</i></p>		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied <i>* see conditions</i>	INSPECTION: Use Group: R-2 Type: SB IMC-2003 IBC-2003	
Proposed Project Description: Install a System 2000 Frontier Boilers Energy Kinetics Boiler		Signature: <i>(KG)</i>	Signature: <i>(C)</i>	
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)				
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied				
Signature: _____ Date: _____				

Permit Taken By: Ldobson	Date Applied For: 05/18/2009	Zoning Approval		
-----------------------------	---------------------------------	------------------------	--	--

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	<p>Zoning Appeal</p> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<p>Historic Preservation</p> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied
	<p>Date: <i>6/15/09</i></p>	<p>Date: _____</p>	<p>Date: _____</p>



CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 102 Cumberland Ave 21-E.9 Use of Building Rental Date 5-18-09
Name and address of owner of appliance Greg Koutos, P.O. Box 1785, Windham, ME 04062

Installer's name and address Charlie Burukhan Heating service Inc. P.O. Box 382
Freeport, ME 04032 Telephone 865-9010

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: System 2000
U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:


- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PNT 6050
- Other _____

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ UL# _____

Type of Fuel Tank

- Oil
- Gas



Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$13,150.00

Permit Fee: \$ 160

Approved

Fire: _____
Ele.: _____
Bldg.: _____

Approved with Conditions

See attached letter or requirement

[Signature]
Inspector's Signature

6/12/09
Date Approved

Signature of Installer [Signature]

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 09-0467	Date Applied For: 05/18/2009	CBL: 021 E009001
------------------------------	--	----------------------------

Location of Construction: 160 CUMBERLAND AVE	Owner Name: KONTOS CAROL & GREGORY C	Owner Address: PO BOX 1785	Phone:
Business Name:	Contractor Name: Charlie Burnham Heating	Contractor Address: PO Box 382 Freeport	Phone: (207) 865-9010
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Multi- Family -(6 D.U.) Install a System 2000 Frontier Boilers Energy Kinetics Boiler	Proposed Project Description: Install a System 2000 Frontier Boilers Energy Kinetics Boiler
---	---

Dept: Zoning	Status: Approved with Conditions	Reviewer: Marge Schmuckal	Approval Date: 06/05/2009
Note:			Ok to Issue: <input checked="" type="checkbox"/>
<p>1) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.</p> <p>2) This property shall remain a six (6) family dwelling. Any change of use shall require a separate permit application for review and approval.</p> <p>3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</p>			
Dept: Building	Status: Approved with Conditions	Reviewer: Chris Hanson	Approval Date: 06/12/2009
Note:			Ok to Issue: <input checked="" type="checkbox"/>
<p>1) Installation shall comply with 2003 International Mechanical Code</p> <p>2) The installation must comply with the State of Maine Gas Regulations.</p>			
Dept: Fire	Status: Approved with Conditions	Reviewer: Capt Keith Gautreau	Approval Date: 06/10/2009
Note:			Ok to Issue: <input checked="" type="checkbox"/>
<p>1) Install shall comply with all manufacture's specifications.</p>			

Comments: 5/18/2009-Ldobson: Need additional information on unit
--