



APPLICATION FOR AMENDMENT TO PERMIT

PERMIT ISSUED
MAY 8 1950
CITY OF PORTLAND

Amendment No. 2

Portland, Maine, February 6, 1950

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for amendment to Permit No. 49/2200 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 158 Cumberland Avenue Within Fire Limits? _____ Dist. No. _____
 Owner's name and address Alice H. Manoogian, 158 Cumberland Avenue Telephone _____
 Lessee's name and address _____ Telephone _____
 Contractor's name and address John Conley, 85 Cumberland Avenue Telephone 4-4988
 Architect _____ Plans filed no. _____ No. of sheets _____
 Proposed use of building Apartment house No. families 3
 Last use _____ " " _____ No. families 4
 Increased cost of work 300. Additional fee .25

Description of Proposed Work

- To construct non-bearing partitions on first floor 28' long forming hall and one 16' long forming new closet.
- To remove approximately 8 6' of bearing partition on first floor so that smokepipe will not pass through partition using 4x8 header over opening. 22" on centers
- To lower first floor ceiling in two rooms, 2x10 ceiling joists, existing, 2x3, 24" on centers, covered with celotex.
- To close up door from kitchen to diningroom and diningroom to hall, first floor, hall door to be ~~xxx~~ covered with incombustible lath and plaster.
- To provide 3 1/2" lally columns, bearing plates top and bottom, this column to relieve weight of new first and second floor partitions, 12" concrete footing.

Details of New Work

Is any plumbing involved in this work? _____ Is any electrical work involved in this work? _____
 Height average grade to top of plate _____ Height average grade to highest point of roof _____
 Size, front _____ depth _____ No. stories _____ solid or filled land? _____ earth or rock? _____
 Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
 Material of underpinning _____ Height _____ Thickness _____
 Kind of roof _____ Rise per foot _____ Roof covering _____
 No. of chimneys _____ Material of chimneys _____ of lining _____
 Framing lumber—Kind _____ Dressed or full size? _____
 Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
 Girders _____ Size _____ Columns under girders _____ Size _____ Max. on centers _____
 Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
 Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
 On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
 Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

Approved:

Signature of Owner by:

Approved: John Conley

Inspector of Buildings