

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
209 Quaker Ridge Rd. Casco, Maine 04015
Phone 207/627-4109 Fax 207/627-7340

September 21, 2016

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn. Captain Petruccelli

Ref: East End Lofts
273 Congress Street
Portland, Maine

Subj: Sprinkler System Certification Letter

This letter is certification that the sprinkler system installed at the above referenced location by Freedom Fire Protection meets the requirements of the National Fire Protection Association 13 Standard (NFPA 13) Light Hazard and Ordinary Hazard Group 2.

Sprinkler permit # FSP12456 was issued by the State of Maine Fire Marshal's office.

The sprinkler system was left in service by Freedom Fire Protection on September 12, 2016.

Regards,