Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/26/14

Fire Alarm System

267 Congress Street, Portland, Maine 04101

SCOPE of WORK: The submittal for this permit is to install a fire alarm system for the building located at 267 Congress. The system will be installed as indicated by the design layout file FA-01 Basement Fire Alarm, FA-02 1st Floor Fire Alarm, FA-03 2nd Fire Alarm, and FA-04 3rd Floor Fire Alarm Drawing. The installation will happening during the buildings ongoing renovation/addition project.

The system has the following features

- Addressable control panel
- LED Annunciator located at the front entrance
- Addressable initiation devices (including manual and automatic initiation)
- Occupant notification devices