LEGEND

- (FT) COMMON PATH OF TRAVEL (IN FEET)
- HS FIRE ALARM AUDIO/VISUAL
- STROBE
- EXIT LIGHT ILLUMINATED (UNSWITCHED)
- EMERGENCY BATTERY UNIT (2 HEADS) 6V DC-10.8 WATTS FOR 90 MINUTES
- P PHOTOELECTRIC SMOKE DETECTOR
- P MANUAL PULL STATION
- R/F HEAT DETECTOR RATE OF RISE FIXED TEMP

REGISTERED ARCHITECT JOHN H. LEASURE No. 310 STATE OF MAINE

REV.	DATE	STATUS
1	1-18-13	CHANGE SIDE ADDITION FOOTPRINT & RELOCATE STAIR
2	4-8-13	STATE FIRE MARSHAL SUBMISSION
3	4-25-13	ISSUED FOR PERMIT

JOHN H. LEASURE ARCHITECT, INC.
6 Q STREET
SOUTH PORTLAND, MAINE 04106

FA-04 3rd Floor Fire Alarm

Protection 1 SECURITY SOLUTIONS — A BETTER CHOICE FOR YOU

Scott Dana, Certified Engineering Technician, NICET IV Cert. #11660			
-	10 Manuel Drive, Portland, Maine 04103 (207) 347-5327	5/13/14	-

ENTIRE BUILDING SPRINKLERED PER NFPA 13

ETZ CHAIM SYNAGOGUE
267 CONGRESS STREET
PORTLAND, MAINE

LIFE SAFETY THIRD FLOOR PLAN

LS4

CITY OF PORTLAND, MAINE — RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/26/14