



... Fire Protection by Computer Design

DEAN AND ALLYN, INC.
116 LEWISTON ROAD
GRAY MAINE 04039
207 657 5646

Job Name : JEWISH MUSEUM BASEMENT
Building : MUSEUM
Location : 267 CONGRESS STREET PORTLAND MAINE
System : ONE
Contract : C141184
Data File : JEWISHMUSEUMBASEMENT.WXF

Hydraulic Design Information Sheet

Name - MAINE JEWISH MUSEUM Date - 2-2-14
 Location - 267 CONGRESS STREET PORTLAND MAINE
 Building - MUSEUM System No. - ONE
 Contractor - DEAN AND ALLYN, INC. Contract No. - C141184
 Calculated By - H. KING Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 7'
 Occupancy - MUSEUM BASEMENT

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling

Made By

Date

E

M	Area of Sprinkler Operation - 1500	System Type	Sprinkler/Nozzle
	Density - .15	(X) Wet	Make RELIABLE
D	Area Per Sprinkler - 126	() Dry	Model F1FR
E	Elevation at Highest Outlet - 6	() Deluge	Size 1/2"
S	Hose Allowance - Inside - 0	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance - 0	() Other	Temp.Rat.155
G	Hose Allowance - Outside - 250		

N

Note CUSHION 12.6 PSI

Calculation Flow Required - 745.5 Press Required - 65.3 CITY
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9-13-2011	Rated Cap.-	Cap. -
T	Time of Test -	@ Press -	Elev.-
E	Static Press - 80	Elev. -	
R	Residual Press - 75		Well
	Flow - 1162		Proof Flow
S	Elevation - 0		

U

P Location - CUMBERLAND AVE

P

L Source of Information - PWD

Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage
S	() Double Row	() Slave Pallet	() Solid Shelf
R	() Mult. Row	() Open Shelf	() Non

T

O C Flue Spacing Clearance:Storage to Ceiling
 A K Longitudinal Transverse

G

E Horizontal Barriers Provided:

Final Calculations - Standard

DEAN AND ALLYN, INC.
 JEWISH MUSEUM BASEMENT

Page 2
 Date 2-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101 to 150	19.77	1.049 120		3.600 0.0	12.467 0.0			K Factor = 5.60	
	0.0	0.1275		3.600	0.459			Vel = 7.34	
	19.77				12.926			K Factor = 5.50	
102 to 150	18.90	1.049 120	1T	5.0 0.0	8.100 5.000	11.391 0.0		K Factor = 5.60	
	18.9	0.1172		0.0	13.100	1.535		Vel = 7.02	
	0.0					12.926		K Factor = 5.26	
103 to 104	59.61	1.38 120		0.0 0.0	7.000 0.0	13.984 0.0		K Factor = 5.60	
	59.61	0.2581		0.0	7.000	1.807		Vel = 12.79	
104 to 105	22.26	1.61 120	1E 1T	4.0 8.0	9.200 12.000	15.791 0.0		K Factor = 5.60	
	81.87	0.2191		0.0	21.200	4.645		Vel = 12.90	
105 to 106	25.31	1.61 120		0.0 0.0	9.000 0.0	20.436 0.0		K Factor = 5.60	
	107.18	0.3607		0.0	9.000	3.246		Vel = 16.89	
106 to 151	27.25	1.61 120	1T	8.0 0.0	3.800 8.000	23.682 0.0		K Factor = 5.60	
	134.43	0.5485		0.0	11.800	6.472		Vel = 21.19	
	0.0					30.154		K Factor = 24.48	
107 to 151	29.20	1.049 120	1E	2.0 0.0	9.300 2.000	27.192 0.0		K Factor = 5.60	
	29.2	0.2621		0.0	11.300	2.962		Vel = 10.84	
	0.0					30.154		K Factor = 5.32	
108 to 152	198.71	2.067 120	1E	5.0 0.0	12.100 5.000	39.228 0.0		K Factor = 5.60	
	198.71	0.3347		0.0	17.100	5.723		Vel = 19.00	
	0.0					44.951		K Factor = 29.64	
109 to 110	19.39	1.049 120		0.0 0.0	7.300 0.0	11.991 0.0		K Factor = 5.60	
	19.39	0.1229		0.0	7.300	0.897		Vel = 7.20	
110 to 111	20.11	1.049 120		0.0 0.0	7.300 0.0	12.888 0.0		K Factor = 5.60	
	39.5	0.4582		0.0	7.300	3.345		Vel = 14.66	
111 to 153	22.56	1.049 120		0.0 0.0	1.600 0.0	16.233 0.0		K Factor = 5.60	
	62.06	1.0569		0.0	1.600	1.691		Vel = 23.04	

Final Calculations - Standard

DEAN AND ALLYN, INC.
 JEWISH MUSEUM BASEMENT

Page 3
 Date 2-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 62.06									
						17.924			K Factor = 14.66	
112 to 153	22.68	1.049 120	1T	5.0 0.0	4.300 5.000	16.398 0.0			K Factor = 5.60	
	22.68	0.1641		0.0	9.300	1.526			Vel = 8.42	
	0.0 22.68									
						17.924			K Factor = 5.36	
113 to 114	110.87	1.61 120		0.0 0.0	8.500 0.0	21.783 0.0			K Factor = 5.60	
	110.87	0.3840		0.0	8.500	3.264			Vel = 17.47	
114 to 115	28.03	1.61 120		0.0 0.0	8.500 0.0	25.047 0.0			K Factor = 5.60	
	138.9	0.5826		0.0	8.500	4.952			Vel = 21.89	
115 to 155	30.67	1.61 120	1T	8.0 0.0	9.000 8.000	29.999 0.0			K Factor = 5.60	
	169.57	0.8428		0.0	17.000	14.327			Vel = 26.72	
	0.0 169.57									
						44.326			K Factor = 25.47	
116 to 117	19.81	1.049 120		0.0 0.0	9.300 0.0	12.513 0.0			K Factor = 5.60	
	19.81	0.1278		0.0	9.300	1.189			Vel = 7.35	
117 to 118	20.73	1.049 120		0.0 0.0	9.300 0.0	13.702 0.0			K Factor = 5.60	
	40.54	0.4809		0.0	9.300	4.472			Vel = 15.05	
118 to 119	23.87	1.049 120		0.0 0.0	9.300 0.0	18.174 0.0			K Factor = 5.60	
	64.41	1.1326		0.0	9.300	10.533			Vel = 23.91	
119 to 120	30.01	1.38 120		0.0 0.0	9.300 0.0	28.707 0.0			K Factor = 5.60	
	94.42	0.6044		0.0	9.300	5.621			Vel = 20.25	
120 to 154	32.81	1.61 120	1T	8.0 0.0	11.800 8.000	34.328 0.0			K Factor = 5.60	
	127.23	0.4953		0.0	19.800	9.807			Vel = 20.05	
154 to 155	0.0	3.26 120		0.0 0.0	12.000 0.0	44.135 0.0				
	127.23	0.0159		0.0	12.000	0.191			Vel = 4.89	
	0.0 127.23									
						44.326			K Factor = 19.11	
150 to 103	38.67	1.049 120		0.0 0.0	2.400 0.0	12.926 0.0				
	38.67	0.4408		0.0	2.400	1.058			Vel = 14.36	

Final Calculations - Standard

DEAN AND ALLYN, INC.
 JEWISH MUSEUM BASEMENT

Page 4
 Date 2-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/UL	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 38.67									
						13.984			K Factor = 10.34	
151 to 108	163.64	1.61 120	1E	4.0 0.0	7.500 4.000	30.154 0.0				
	163.64	0.7890		0.0	11.500	9.074			Vel = 25.79	
	0.0 163.64									
						39.228			K Factor = 26.13	
152 to 61	198.71	3.26 120	1T	20.159 0.0	10.900 20.159	44.951 0.0				
	198.71	0.0364		0.0	31.059	1.130			Vel = 7.64	
	0.0 198.71									
						46.081			K Factor = 29.27	
153 to 113	84.73	1.38 120		0.0 0.0	7.800 0.0	17.924 0.0				
	84.73	0.4947		0.0	7.800	3.859			Vel = 18.17	
	0.0 84.73									
						21.783			K Factor = 18.15	
155 to 61	296.80	3.26 120	1T	20.159 0.0	2.800 20.159	44.326 0.0				
	296.8	0.0764		0.0	22.959	1.755			Vel = 11.41	
61 to TR	198.71	3.26 120	1E	9.408 0.0	4.800 9.408	46.081 0.0				
	495.51	0.1973		0.0	14.208	2.803			Vel = 19.05	
TR to FF	0.0	3.26 120	1E 1Z	9.408 9.408	6.000 18.815	48.884 7.599			* Fixed loss = 5.000	
	495.51	0.1973		0.0	24.815	4.896			Vel = 19.05	
FF to CTY	0.0	6.16 120	1G 1T	3.236 32.359	400.000 35.595	61.379 0.0				
	495.51	0.0089		0.0	435.595	3.876			Vel = 5.33	
	250.00 745.51								Qa = 250.00 K Factor = 92.29	

Fittings Used Summary

DEAN AND ALLYN, INC.
 JEWISH MUSEUM BASEMENT

Page 5
 Date 2-2-14

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.
 JEWISH MUSEUM BASEMENT

Page 6
 Date 2-2-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	6.0	5.6	12.47	na	19.77	.15	126	7.0
102	6.0	5.6	11.39	na	18.9	.15	126	7.0
103	6.0	5.6	13.98	na	20.94	.15	126	7.0
104	6.0	5.6	15.79	na	22.25	.15	126	7.0
105	6.0	5.6	20.44	na	25.32	.15	126	7.0
106	6.0	5.6	23.68	na	27.25	.15	126	7.0
107	6.0	5.6	27.19	na	29.2	.15	126	7.0
108	6.0	5.6	39.23	na	35.07	.15	126	7.0
109	6.0	5.6	11.99	na	19.39	.15	126	7.0
110	6.0	5.6	12.89	na	20.1	.15	126	7.0
111	6.0	5.6	16.23	na	22.56	.15	126	7.0
112	6.0	5.6	16.4	na	22.68	.15	126	7.0
113	6.0	5.6	21.78	na	26.14	.15	126	7.0
114	6.0	5.6	25.05	na	28.03	.15	126	7.0
115	6.0	5.6	30.0	na	30.67	.15	126	7.0
116	6.0	5.6	12.51	na	19.81	.15	126	7.0
117	6.0	5.6	13.7	na	20.73	.15	126	7.0
118	6.0	5.6	18.17	na	23.87	.15	126	7.0
119	6.0	5.6	28.71	na	30.0	.15	126	7.0
120	6.0	5.6	34.33	na	32.81	.15	126	7.0
154	6.0		44.13	na				
150	6.0		12.93	na				
151	6.0		30.15	na				
152	6.0		44.95	na				
153	6.0		17.92	na				
155	6.0		44.33	na				
61	6.0		46.08	na				
TR	6.0		48.88	na				
FF	0.0		61.38	na				
CTY	0.0		65.25	na	250.0			

The maximum velocity is 26.72 and it occurs in the pipe between nodes 115 and 155

Water Supply Curve (C)

DEAN AND ALLYN, INC.
JEWISH MUSEUM BASEMENT

Page 7
Date 2-2-14

City Water Supply:
C1 - Static Pressure : 80
C2 - Residual Pressure: 75
C2 - Residual Flow : 1162

