



- LEGEND**
- (FT) COMMON PATH OF TRAVEL (IN FEET)
 - Fire alarm symbol FIRE ALARM AUDIOVISUAL
 - Strobe symbol STROBE
 - Exst. Light symbol EXST. LIGHT ILLUMINATED (UNSWITCHED)
 - Battery symbol EMERGENCY BATTERY UNIT (2 HEADS) 6V DC-10.8 WATTS FOR 90 MINUTES
 - Smoke detector symbol PHOTOELECTRIC SMOKE DETECTOR
 - Manual pull station symbol MANUAL PULL STATION
 - Heat detector symbol HEAT DETECTOR RATE OF RISE FIXED TEMP



REV.	DATE	STATUS
1	1-18-13	CHANGE SIZE ADDITION FOOTPRINT & RELOCATE STAIR
2	4-8-13	STATE FIRE MARSHAL SUBMISSION
3	4-25-13	ISSUED FOR PERMIT

FA-04 3rd Floor Fire Alarm

Protection 1
 SECURITY SOLUTIONS
 Scott Dana, Certified Engineering Technician, NICET IV Cert. #11660
 10 Manuel Drive, Portland, Maine 04103 (207) 347-5327 5/13/14

ENTIRE BUILDING SPRINKLERED PER NFPA 13

ETZ CHAIM SYNAGOGUE
 267 CONGRESS STREET
 PORTLAND, MAINE
 LIFE SAFETY THIRD FLOOR PLAN

