Protection 1 Branch 11660 | **System Outputs**

10 Manual Drive, Portland, ME 04103 PH# 1-800-310-5011 | **Control Unit Annunciation** | **Notification** | **Safety Control**

Protection 1 SECURITY SOLUTIONS — A BETTER CHOICE FOR YOU

System Inputs

	Actuate common alarm signal indicator	Actuate audible alarm system	Actuate common supervisory signal indicator	Actuate audible supervisory signal	Actuate common trouble signal indicator	Actuate Basment floor evacuation signals	Actuate 1st Floor Evacuation Signals	Actuate 2nd Floor Evacuation Signal	Actuate 3rd Floor Evacuation Signals	Actuate 4th Floor Evacuation Signals	Actuate 5th Floor Evacuation Signals	Transmit fire alarm signal to supervising station	Transmit supervisory signal to supervising	Transmit trouble signal to supervising station
System Pull Stations	X	X				X	X	X	X				X	
System Smoke Detectors	X	X				X	X	X	X				X	
System Heat Detectors	X	X				X	X	X	X				X	
Sprinkler Water Flow	X	X												
Sprinkler Gate Valve Tamper				X	X									X
Sprinkler Air Pressure														
FACP AC Loss				X	X									
FACP Low Battery				X	X									
FACP Ground Fault				X	X									
Phone Line #1 Fail				X	X									
Phone Line #2 Fail				X	X									
ETZ Chaim Synagogue														
267 Congress Street														
Portland, Maine 04101														