

CITY OF PORTLAND FIRE DEPARTMENT  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207)874-8400

Remove excess storage in retail space.	In process, will complete by December 31, 2016
12. NFPA 70- ARTICLE 110 B CERTIFY ELECTRICAL SYSTEM. Listed or labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling. <i>Have electrical system inspected and repaired.</i>	Will schedule inspection for October 2016 and outcome of inspection will determine repair/alteration timeline
13. NFPA 70 MISSING BREAKER IN PANEL. Refer to NFPA 70, National Electrical Code, for information on missing breakers in an electrical panel. <i>Repair breakers in electrical panel.</i>	In process - will complete by December 31, 2016
14. NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED. The areas described in table 31.3.2.1.1 shall be protected as indicated: boiler and fuel-fired heater rooms serving more than a single dwelling unit (minimum separation/protection is 1 hour or sprinklers). <i>Install sprinkler head over gas hot water heater.</i>	per Asst Fire Chief Gautreau, not required for the current classification of building.

**VIOLATOR CERTIFICATION**

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny. If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

9/2/2016  
 Date

*Denise Yob / James Shurtz*  
 Responsible Party 1

**SEEN AND AGREED**

9/2/2016  
 Date

*Capt. Petrucci*  
 Fire Prevention Bureau

\* Extension until February 28, 2016 per AC Keith Gautreau *(Signature)* 12.29.16