

- KEY NOTES**
1. UTILITY POLE TO BE REPLACED BY UTILITY. PROVIDE RISER PER DETAIL SHOWN.
  2. PROVIDE SECONDARY POWER CONDUITS FROM TRANSFORMER PAD TO MANHOLE FOR FUTURE BUILDING. PROVIDE PULL ROPE
  3. PROVIDE TRANSFORMER PAD IN ACCORDANCE WITH UTILITY REQUIREMENTS.
  4. SEE SITE CIVIL DRAWINGS FOR SITE LIGHTING/RECEPTACLES ON BOLLARDS.

**KAPLAN THOMPSON ARCHITECTS**  
 424 FORE ST.  
 PORTLAND, ME 04101  
 207-842-2888

**PORTLAND HOUSING MAINE**  
 14 BAXTER BLVD  
 PORTLAND, ME 04101  
 P: 207.773.4753

**AVESTA HOUSING**  
 307 CUMBERLAND AVE  
 PORTLAND, ME 04101  
 P: 207.553.7777

**CARROLL ASSOCIATES LANDSCAPE ARCHITECTS**  
 217 COMMERCIAL STREET, STE 200  
 PORTLAND, MAINE 04101  
 207.772.1592 V. F. 207.772.8712

**BECKER STRUCTURAL ENGINEERS**  
 75 YORK ST.  
 PORTLAND, ME 04101  
 P: 207.879.1838

**RANSOM Consulting Engineers and Scientists**  
 400 COMMERCIAL ST.  
 SUITE 404  
 PORTLAND, ME 04101  
 P: 207.772.2891


**APEX ENGINEERING**  
 190 US ROUTE ONE  
 PMB 346 FALMOUTH, ME  
 04105  
 P: 207.847.3445

**100% ISSUE FOR CONSTRUCTION**

Project:  
**BAYSIDE ANCHOR**  
 PHDC & Avesta  
 81 East Oxford Street  
 Portland, ME

Drawing: ELECTRICAL SITE PLAN  
 Scale: 3/32" = 1'-0"  
 Date: 9/1/15

Drawn by: ACY  
 Revised:



E500