

Inspection Services
P. Samuel Hoffses
Chief



DONE
[Signature]

Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

July 17, 1996

Larry Gaudet
277 Pleasant Avenue
South Portland, Maine 04106

COMPLETED
[Signature]

RE: 47 & 49 Boyd Street

Dear Larry,

On July 11, 1996, I conducted an electrical inspection at the above referenced address and found the following violations and unsafe conditions which present a **clear and present danger to the occupants of the building**. These conditions must be corrected by a licensed Master Electrician.

1. Replace old service entrance cable on the outside of the building
2. Install a new panel with main breaker or a disconnect and panel to replace the owner installed panel
3. All unused wiring in the basement area must be removed..
4. A new ground rod must be installed
5. Grounding of both services must be brought up to code
6. An outside light at the entrance on the photo eye or a timer on the owners' panel must be installed.
7. Bond around the water meter and check connections.

These items must be corrected within 30 days of receipt of this letter at which time I shall be forced to take further action to ensure compliance.

If you have any questions regarding this matter please do not hesitate to contact me at 874-8694.

Sincerely,

Michael A. Collins
Chief Electrical Inspector
City of Portland

cc: P. Samuel Hoffses, C, Insp Svcs Div
M. Leary, CEO
Richard Knedler, Knedler Electric