

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
 389 Congress Street
 Portland, Maine 04101

Inspection Violations

Owner/Manager BOYD STREET PARTNERS LLC		Inspector Jon Rioux	Inspection Date 7/31/2007
Location 47 BOYD ST	CBL 022 I003001	Status Re-Inspect 10 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-116.5	Interior	2	2B	Various locations	
Violation: Fire Protection					
Notes: Need to be remounted (fix brackets) All three smks are working however two are haning by the wires, and one is resting on the door header.					
2) 6-108.3	Interior	2	2B	Various locations	
Violation: Exterior windows, doors and skylights					
Notes: window needs to be fixed so it shuts					

Comments: