
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager BOYD STREET PARTNERS LLC		Inspector Jon Rioux	Inspection Date 7/31/2007
Location 47 BOYD ST	CBL 022 I003001	Status Re-Inspect 10 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-116.5	Interior	2	2B	Various locations	
Violation:	Fire Protection				
Notes:	Need to be remounted (fix brackets) All three smokes are working however two are hanging by the wires, and one is resting on the door header.				
2) 6-108.3	Interior	2	2B	Various locations	
Violation:	Exterior windows, doors and skylights				
Notes:	window needs to be fixed so it shuts properly				

Comments: