
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

| | | | |
|--|---------------------------|-------------------------------------|---|
| Owner/Manager BOYD STREET PARTNERS LLC | | Inspector Jon Rioux | Inspection Date 7/31/2007 |
| Location 47 BOYD ST | CBL 022 1003001 | Status Re-Inspect 10 Days | Inspection Type Complaint-Social Services/Gener |

| Code | Int/Ext | Floor | Unit No. | Area | Compliance Date |
|---|----------------|--------------|-----------------|-------------------|------------------------|
| 1) 6-116.5 | Interior | 2 | 2B | Various locations | 08/20/2007 |
| Violation: Fire Protection | | | | | |
| Notes: Need to be remounted (fix brackets) All three smokes are working however two are hanging by the wires, and one is resting on the door header. | | | | | |
| 2) 6-108.3 | Interior | 2 | 2B | Various locations | 08/20/2007 |
| Violation: Exterior windows, doors and skylights | | | | | |
| Notes: window needs to be fixed so it shuts properly | | | | | |

Comments: