


## 55.95 kW<sub>DC</sub> Photovoltaic System Annual Production Estimate: 60,823 kWh





142 Presumpscot Street Portland, ME 04103 (207) 221-6342

Customer Name:

Bayside Anchor (RFP) 81 East Oxford Street Portland, ME 04101

System Type:

Photovoltaic Array

Designed by: L


Date:

June 24, 2016

SITE PLAN

SHEET A01

© Copyright ReVision Energy



Project Design Notes -

AC System: 43.2 kW<sub>AC</sub>

Intra-Row Spacing: 0.6'

Roof Dimensions: Shown

Building Height: 67'

DC System: 55.95 kW<sub>DC</sub> Photovoltaic Array

(167) 335-watt, 72-cell PV Modules

Dimensions: 77.17" x 39.37" x 1.81"

Module Type: LG335 S2W-G4 MonoX

(3) SolarEdge 14.4kW Grid-tied Inverters

(84) SolarEdge P700 DC Optimizers

Racking System: Panel Claw 5D HD III


Dead Load of Solar Array: 6 to 8 psf (typ) Setback from Roof Edge: 4' (required)

Roof Type: Fully Adhered EPDM or equivalent

Roof Mount, Ballasted Fixed Tilt

Array Tilt: 5° Array Azimuth: 228°

### 55.95 kW<sub>DC</sub> Photovoltaic System Annual Production Estimate: 60,823 kWh





142 Presumpscot Street Portland, ME 04103 (207) 221-6342

Customer Name:

Bayside Anchor (RFP) 81 East Oxford Street Portland, ME 04101

System Type:

Photovoltaic Array

Designed by: LE

Date:


June 24, 2016

SITE PLAN

SHEET A02

© Copyright ReVision Energy

# $55.95 \text{ kW}_{DC}$ Photovoltaic System Annual Production Estimate: 60,823 kWh





142 Presumpscot Street Portland, ME 04103 (207) 221-6342

**Customer Name:** 

Bayside Anchor (RFP) 81 East Oxford Street Portland, ME 04101

System Type:

Photovoltaic Array

Designed by:

Date: June 24, 2016

ONE-LINE DIAGRAM

SHEET E01

© Copyright ReVision Energy

# $55.95 \text{ kW}_{DC}$ Photovoltaic System Annual Production Estimate: 60,823 kWh

#### General Electrical Design Notes

- All equipment is outdoor rated and UL listed for 600V DC.
- All conductors are copper unless specified otherwise.
- System-wide voltage drop shall not exceed 3%.
- Inverter system is composed of module strings utilizing SolarEdge P700 optimizers (two modules per optimizer). String voltages are controlled by the 208V, 3-phase SolarEdge inverter ( < 600 V DC).
- Lowest expected ambient temperature is based on ASHRAE Extreme Min for the specified location.
- Average high temperature is based on ASHRAE 2% Avg. for the specified location.
- Remote AC Disconnect Switch furnished per local AHJ requirement.
- Point of Interconnection: Supply Side Connection at main service.
- All photovoltaic equipment is rated for use and listed by a recognized laboratory.
- Grounding and bonding procedures for all photovoltaic equipment comply with NEC 2014.
- Rapid shutdown requirements are in accordance with NEC 690.12.
- Conduit between subarrays, combiners, and disconnects shall take the shortest reasonable path.
- Space requirements for electrical equipment shall comply with NEC Article 110.
- Any plaques shall be of metal or plastic construction, with engraved or machine printed lettering, or electro-plating, in a red background with white lettering, a minimum of 3/8" height and all capital letters.



142 Presumpscot Street Portland, ME 04103 (207) 221-6342

**Customer Name:** 

Bayside Anchor (RFP) 81 East Oxford Street Portland, ME 04101

System Type:

Photovoltaic Array


Designed by: LB

Date: June 24, 2016

ONE-LINE DIAGRAM

SHEET E02

© Copyright ReVision Energy





142 Presumpscot Street Portland, ME 04103 (207) 221-6342

Customer Name:

Bayside Anchor (RFP) 81 East Oxford Street Portland, ME 04101

System Type:

Photovoltaic Array

Designed by: LB

Date:

June 24, 2016

LABELING

SHEET E03

© Copyright ReVision Energy