

Portland, Maine



Yes. Life's good here.

Jerome F. LaMoria Fire Chief, Fire Department

Portland Fire Department Fire Prevention Bureau 380 Congress St Portland, ME 04101

July 1, 2015

Kevin G. Oakes PO Box 10402 Portland, ME 04104

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at 161 Cumberland Ave on 06/30/2015 revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager OAKES KEVIN G				Inspector Daniel Small		Inspection Date 6/30/2015	
Location CBL			Status		Inspection Type		
161 CUMBERLAND AVE		022 J025001		Failed		Fire Company-FP Routine Inspec	
Code	Int/Ext Floor			Unit No. Area		Compliance Date	
1) 73.10							
Violation:	NFPA 101-7.2.4.3.1 FIRE BARRIER REQUIRES MAINTENANCE; Fire barriers separating buildings or areas between which there are horizontal exits shall have a minimum 2-hour fire resistance rating, unless otherwise provided in 7.2.4.4.1, and shall provide a separation that is continuous to the finished grounded level.						
Notes:	HOLES IN STAIRWAY WALLS						
2) 80.28		<u> </u>					
Violation:	NFPA 101- 7.5.1.1 EXIT OBSTRUCTED; Where exits are not immediately accessible from an open floor area, continuous passageways, aisles, or corridors leading directly to every exit shall be maintained and shall be arranged to provide access for each occupant to not less than two exits by separate ways of travel, unless otherwise provided in 7.5.1.1.3 and 7.5.1.1.4.						
Notes:	DEBRIS IN STAIRWAYS						
3) 71.05							
Violation:	CO ALARMS REQUIRED						
Notes:							
4) 71.25							
Violation:	SMOKE ALARMS REQUIRED						
Notes:							
5) 3.011							
Violation:	NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED; THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED: BOILER AND FUEL-FIRED HEATER ROOMS SERVING MORE THAN A SINGLE DWELLING UNIT (MINIMUM SEPARATION/PROTECTION IS 1 HOUR OR SPRINKLERS)						
Notes:							
6) 55.511							
Violation:	NVPA 1, CHAPTER 10 - 10.11.6 HIBACHI OR GRILL ON BALCONY; NO HIBACHI, GAS-FIRED GRILL, CHARCOAL GRILL, OR OTHER SIMILAR DEVICES USED FOR COOKING, HEATING, OROTHER PURPOSE, SHALL BE USED OR KINDLED ON ANY BALCONY OR UNDER ANY OVERHANG PORTION OR WITHIN 10 FTOF ANY STRUCTURE						
Notes:	**************************************						
Comments:							

DISTRICT COURT Location: Portland

Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Kevin G. Oakes Defendant

SUMMONS NUMBER:

353752

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on August 10, 2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an inperson meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on August 10, 2015.

Dated: $7/\sqrt{\frac{1}{15}}$

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council City of Portland

City of Portland 389 Congress St Portland, ME 04101 207-874-8480