

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that
GOTSHALK SHIRA J

Located at
33 SMITH ST

PERMIT ID: 2017-00207 ISSUE DATE: 06/05/2017 CBL: 022 L016001

has permission to **Renovations to 1st and 2nd floor units. Remove stair from second floor, reconfigure bedrooms, add new plumbing fixtures, new cabinetry, new windows, repair existing walls and ceilings.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Brian Stephens

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Three dwelling units

Building Inspections

Use Group: R-2 **Type:** 5B
Apartment House (3 Units)
Occupant Load = 13
Non-Sprinkled
First & Second Floors
MUBEC/IBC-2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Electric

Final Inspection

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00207	Date Applied For: 02/17/2017	CBL: 022 L016001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Three dwelling units		Proposed Project Description: Renovations to 1st and 2nd floor units. Remove stair from second floor, reconfigure bedrooms, add new plumbing fixtures, new cabinetry, new windows, repair existing walls and ceilings.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 05/03/2017
Note: R-6 zone Interior renovations - OK		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.				
2) This property shall remain three dwelling units. Any change of use shall require a separate permit application for review and approval.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Brian Stephens	Approval Date: 06/05/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Beams shall be supported by posts and solid blocking to carry the load path to another beam, foundation or footing.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
4) Draftstopping and Fireblocking in combustible concealed spaces and locations shall be in accordance with IBC Sec. 717 or IRC Sec. R302.11 & 302.12				
5) All floors and walls that separate dwelling units or dwelling units and common areas are required to meet a 1 hour fire rated assembly and sound transmission rating of 45 STC.				
6) Egress size windows are required (1) in each sleeping room per IRC Sec. R310 or per the State Fire Marshal policies for existing buildings.				
7) All pre-1978 building and housing stock shall meet State and Federal regulations for lead abatement.				
8) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
9) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings undergoing alterations, hard wired to the electrical system. Interconnection is required, where permanent wiring is feasible, which shall be verified upon inspection.				
10) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2.				
11) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4				
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 04/19/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				

