147 Cumberland Ave.
Portland, ME 04101

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/20/13
Planner: Benjamin Wallace Jr

EXISTING PLAN VIEW
STAIR WELL

ELEVATION BASEMENT VIEW
EAST WALL

PROPOSED BASEMENT
PLAN VIEW

Need contineuos handrail 34" - 38" above leading edge of the tread and return to the wall

1-hour fire door assembly needed

1-hour fire wall assembly
Wall type 1

PROPOSED ELEVATED VIEW

PROPOSED BASEMENT WALLS + DOOR ADDITIONS
PER FIRE MARSHALL

EMT. Ceiling height 79"

RECEIVED
MAR 06 2013
Dept. of Building Inspections
City of Portland Maine