Portland, Maine



Yes. Life's good here.

September 23, 2015

Harriman Chien S

2037 Clinton Ave # A

Alameda, CA 94501

CBL: 022 L018001

Located at 0141 CUMBERLAND AVE

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

A/C Keth Santen

Fire Prevention Bureau

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager Harriman Chien S				Inspector John Cenate		Inspection Date 9/22/2015	
Location CBL				Status		Inspection Type	
0141	CUMBERLAND A	022 L01	18001	Failed		Fire Company-FP Routine Inspec	
Co	de in	t/Ext	Floor	Unit No.	Area	Compliance Date	
1) 73.	25						
Violatio		NFPA 101-31.3.2.1 AND 31.3.2.1.1 PROTECTION OF HAZARDOUS AREAS NOT PROVIDED; ANY HAZARDOUS AREA SHALL BE PROTECTED IN ACCORDANCE WITH SECTION 8.7.					
	THE AREAS DESCRIBED IN TABLE 31.3.2.1.1 SHALL BE PROTECTED AS INDICATED.						
Notes:	WASHER AND	WASHER AND DRYER IN THE REAR STAIRWAY					
2) 55.2	25						
Violatio	out with an exi accordance wi	NFPA 101- 31.3.4.5.1 SMOKE ALARMS REQUIRED; In buildings other than those equipped through out with an existing, complete automatic smoke detection system, smoke alarms shall be installed in accordance with 9.6.2.10, as modified by 31.3.4.5.2, outside every sleeping area in the immediate vicinity of the bedrooms and on all levels of the dwelling unit, including basements.					
Notes:	EACH SLEEPI	EACH SLEEPING AREA					
3) 89.0	05						
Violatio	on: NFPA 1 EXCE LOAD.	NFPA 1 EXCESSIVE/DISORDERLY STORAGE; REFERENCE NFPA 1 FOR EXCESSIVE FUEL-LOAD.					
Notes:	STORAGE ON	STORAGE ON FRONT STAIRS, EXCESSIVE STORAGE IN THE BASEMENT					
4) 91.2	20						
Violatio	installations sh temporary wirir construction, re	NFPA 70- 590.6 EXTENSION CORDS; Ground-fault protection for personnel for all temporary wiring installations shall be provided to comply with 590.6(A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment, or similar activities.					
Notes:		EXTENSION CORDS USED AS PERMANENT 1 ST FLOOR APARTMENT AND ON A WATER HEATER IN THE BASEMENT					

Comments:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Chien Harriman Defendant

SUMMONS NUMBER:

354913

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 11/09/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meserve was a liternative arrangements to relieve you of the requirement to appear in Court on 11/09/2015.

Dated: 9/29/15

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Council City of Portland 389 Congress St

Portland, ME 04101

207-874-8480