

## Jeanie Bourke - Re: Mezzanine detail

---

**From:** Jeanie Bourke  
**To:** Tracie Reed  
**Date:** 9/29/2015 9:08 AM  
**Subject:** Re: Mezzanine detail  
**CC:** Heather Sanborn; Nathan Sanborn

---

Morning Tracie,

Thanks for discussing this problematic situation on the mezzanine, and revising the guard detail, in order to limit the allowable square foot floor area for storage that is accessed by an alternating tread stair. This will suffice to meet the code as opposed to redesigning the floor to achieve this maximum floor area.

I am approving the permit, it remains in review with the fire department.

Have a great day.

Jeanie

*Jeanie Bourke*  
*CEO/LPI/Plan Reviewer*

**City of Portland**  
**Planning & Urban Development Dept./ Inspections Division**  
**389 Congress St. Rm 315**  
**Portland, ME 04101**  
**[jmb@portlandmaine.gov](mailto:jmb@portlandmaine.gov)**  
**Direct: (207) 874-8715**  
**Office: (207) 874-8703**  
**Permit status can be viewed at: <http://www.portlandmaine.gov/792/Permit-Status>**

>>> Tracie Reed <[traciereed@dextrouscreative.com](mailto:traciereed@dextrouscreative.com)> 9/28/2015 2:09 PM >>>

Jeanie, Thanks for the quick turnaround in terms of your comments to my revised drawings on Friday. I've attached a slightly revised detail for the mezzanine. To clarify the inner wall is 42" high with 1/2" plywood on one side. In order to make it unappealing to sit on or remove I've tied it in to the front wall every 36" with 2x4's that are set down just enough that it wouldn't be comfortable to sit atop.

Let me know what you think. Hope you had a great weekend.

Best,  
Tracie