

Rising Tide Brewing Expansion

	IBC 2009		NFPA 101 2009	
1 floors above grade	502.1			
Sprinklers		NFPA 13		NFPA 13
Fire Alarm		Monitored Fire Alarm Required		Monitored Fire Alarm Required
Smoke and CO Detectors		Smoke and CO detectors required		Smoke and CO detectors required
Occupant Load	T 1004.1.1		7.3.1.2	
		Assembly 1333 sf / 7 = 191 occ.		Assembly 1333 sf / 7 = 191 occ.
		Brewery Area 1229 sf / 100 sf = 13 occ.		Brewery Area 1229 sf / 100 sf = 13 occ.
		Mezzanine Business Use = 456 sf / 100 = 5 occ.		Mezzanine Business Use = 456 sf / 100 = 5 occ.
		Existing Brewery Area = 3,020 sf		
		Existing Tasting Room = 829 sf		
		Existing Office Areas = 209 sf		
		Total Brewing Areas = 4,249 sf		
		Total Tasting Room Areas = 2,162 sf		
		Total Office Areas = 665 sf		
Use Group(s)	309.1	Factory Industrial Low-Hazard (F-2) (brewery)	6.1.10	General Industrial Occupancy
	3031	(A-2) Assembly	12.1	Assembly (<300)
Construction Type	T 503	3B - mixed combustibile unprotected		III (000) combustibile unprotected
Building Height and Area	T503	A2 = 2 stories and 9,500 sf footprint F2 = 3 story and 18,000 sf footprint		
Building Height		55'		

Building Elements	T 601	0 hr Structural Frame		12.1.6	Assembly allowed on first floor only 1 if under 1000 occ. In type III (000) building
	T 602	2 hr Bearing Walls Exterior			
	T 601	0 hr Bearing Walls Interior			
	T 601	0 hr Non-Bearing Walls Interior			
	T 602	0 hr Non-Bearing Walls Exterior (sep. dist >= 30')			
	T 602	1 hr Non-Bearing Walls Exterior (sep. dist <30')			
	705.5	Exterior Wall with >10' sep. needs rating only from inside			
	T 601	0 hr Floor Construction (1hr between units)			
	T 601	0 hr Roof Construction			
Separations	508.4			6.1.14.1	
		F-2 and A-2 = 1hr with sprinkler			Industrial and Assembly = 1hr with sprinkler
	508.2.5	Boiler room 1hr			
	708	1 hr Mechanical Shaft < 4 stories			
	1022.1	1 hr Stair Shaft < 4 stories			
	1018.1	1/2 hr Corridor		30.3.6.1.2	1/2 hr corridor
	508.2.5	1 hr Boiler Room		30.3.2.1.1	1 hr Boiler Room
	508.2.5	1 hr Trash Room		30.3.2.1.1	1 hr Trash Room
	508.2.5	1 hr Storage Room		30.3.2.1.1	1 hr Storage Room
Distances and Exits	1021.1	2 Exits required		7.4.1.1	2 Means of Egress required
	1016.1	200' Travel Distance to exits no sprinklers 1/2 diagonal distance exit separation without sprinkler		12.2.6.2	200' Maximum Travel distance
	1014.3	75' Common Path of Travel		12.2.5.1.2	75' Common Path of Travel for less than 50 occ.
	1018.4	20' Dead End		12.2.5.6.2	20' Dead End
				28.2.6.2	125' Travel Distance within Dwelling to Corridor
Unprotected Openings	T 705.8	15% when exterior wall sep. dist. is 3'>5'			
	T 705.8	45% when exterior wall sep. dist. is 10'>15'			
	T 705.8	75% when exterior wall sep. dist. is 15'>20'			
	T 705.8	Unlimited when exterior wall sep. dist. is 25'>30'			
	T 705.8	Unlimited when exterior wall sep. dist. is >30'			

Egress Stairs		1009.1	Occ. Load >50 = 44" min width	24.2.5.4	36" min. stair width
		1009.1	Occ. Load <=50 = 36" min width	7.2.2.2.1.2(B)	44" min. over 50 occ.
		1003.3	Handrails can protrude into stair 4.5" max	7.2.2.2.1.2	Handrails can protrude into stair 4.5" max
		1005.2	Door Swings may not reduce egress width by > 1/2		
		1009.2	80" min headroom	7.2.2.2.1.1(a)	6'-8" min. headroom
		1009.3	7" max. riser	7.2.2.2.1.1(a)	7" max. riser
		1009.3	11" min Tread depth	7.2.2.2.1.1(a)	11" min. tread
		1009.6	12' max. total rise between floors or landings	7.2.2.2.1.1(a)	12' max. height between landings
Ramps		1010.2	1:12 (8%) Max slope	7.2.5.2(a)	1:12 max. slope
		1010.6	60" long landings at top and bottom		
		1010.6	2% max slope of landings	7.2.5.2(a)	1:48 max. cross slope
		1010.8	>6" rise must have handrails on both sides of ramp		
Egress Corridors		1018.2	44" min. when Occ. > 50		
		1018.2	36" min. when Occ. <= 50		
		1018.2	24" min. at service corridors to mechanical equipment		
Accessibility		Ch 11 of IBC 2009 does not apply as State of ME did not adopt it as part of MUBEC			
		Retail and Restaurant Spaces must meet ADA 2010			
		All common spaces and retail areas are designed to meet ADA 2010			
Plumbing	Restaurants	Employees = 20			
		770 sf of tables and chairs 15sf per occ = 52			
		1333 sf of chairs 7 sf per occ = 191			
		131 Males			
		2 male toilets, 1 urinal, 1 lavatory			
		131 Females			
		4 female toilets, 2 lavatory			