Reviewed for Code Compliance
Inspection Division
Date: 08/02/17

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 6" SOUND BATT -½" RESILIENT SOUND CHANNEL AT 16" O.C. - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NB	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB - 18 GAUGE 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - 6" ROXUL SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB - PROVIDE HEAD SLIP TRACK

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1B	1 HR	V450	50-54	N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - LAYER OF 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
NA	N/A	N/A		N/A

GRAPHIC DEPICTION	DESCRIPTION
	- ¾" T & G FLOOR SHEATHING (SEE STRUCTURAL) - 2X10 JOISTS AT 12" O.C. (SEE STRUCTURAL) - 6" SOUND BATT INSULATION - MTL HAT CHANNEL AT 16" O.C. FASTENED TO JOISTS - LAYER OF TYPE 'X' 5/8" GWB

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
F1	N/A	V450	-	N/A

GRAPHIC DEPICTION	DESCRIPTION
	- LAYER OF TYPE 'X' 5/8" GWB -½" RESILIENT SOUND CHANNEL AT 16" O.C. - 18 GAUGE 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - 6" ROXUL SOUND BATT INSULATION -½" RESILIENT SOUND CHANNEL AT 16" O.C. - LAYER OF TYPE 'X' 5/8" GWB - PROVIDE HEAD SLIP TRACK

TYPE	FIRE RATING	UL NUMBER	STC RATING	IIC RATING
1A	1 HR	V450	50-54	N/A

WALL TYPE NOTES

1.) REFER TO STRUCTURAL DRAWINGS FOR STUD SIZE AND SPACING

2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES

3.) PROVIDE ⅝" GWB BEHIND ALL TUBS AND SHOWERS AT EXTERIOR WALLS AND FIRE RATED ASSEMBLIES. PROVIDE ADDITIONAL LAYER OF GWB TO COVER TUB AND SHOWER FLANGE. EXTEND ADDED LAYER ALONG ADJACENT WALLS AND ADJUST DOOR JAMB WIDTHS AS REQUIRED.

4.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTIUOUS PLANE, ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE

5.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT.

6.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED

7.) ALL FIRE WALLS TO EXTEND TO DECK ABOVE, PROVIDE FIRE CAULKING AND BLOCKING AT ALL TOPS OF WALLS

8.) ALL NON-BEARING LIGHT GAUGE WALLS TO HAVE SLIP HEAD TRACKS WHEN FRAMED TO DECK OR BEAM EDGE

REGISTERED ARCHITECT
RYAN J. SENATORE
No. 3322
STATE OF MAINE

© 2017 RYAN SENATORE ARCHITECTURE

RISING TIDE BREWING - EXPANSION

103 FOX STREET
PORTLAND, MAINE 04101

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:

DATE:	MAY 12, 2017
PROJECT No.	1718
DRAWN BY:	JPF
CHECKED BY:	RJS
SCALE:	AS NOTED

SHEET TITLE:
WALL AND FLOOR ASSEMBLIES

A0-1