

Installer's Guide

From Dwg. C041884 Rev. 9

MINIMUM CLEARANCE TO COMBUSTIBLE MATERIALS

UPFLOW

SIDES 0 IN.
REAR 0 IN.
FRONT 1 IN.
TOP 1 IN.
FLUE 0 IN.

HORIZONTAL FLUE DISCHARGE ON THE LEAD

SIDES 0 IN.
REAR 0 IN.
FRONT 3 IN.
TOP 1 IN.
FLUE 0 IN.

ALCOVE

SIDES 1 IN.
REAR 0 IN.
FRONT 0 IN.
TOP 1 IN.
FLUE 0 IN.

CLOSET

SIDES 1 IN.
REAR 1 IN.
FRONT 3 IN.
TOP 1 IN.
FLUE 0 IN.

1. UNIT C041884 REQUIRES 3" DIAMETER VENT PIPE.
2. DIAMETER OF VENT PIPE MAY BE LIMITED TO 2-1/2" OR 2" ON SOME MODELS AT DIFFERENT ALTITUDES. REFER TO THE VENT LENGTH TABLE FOR PROPER APPLICATION.

***UH1 OUTLINE DRAWING, UPFLOW / HORIZONTAL**
(ALL DIMENSIONS ARE IN INCHES)

MODEL (SEE NOTE 1 & 2)

DIM. F.	DIM. E.	DIM. D.	DIM. C.	DIM. B.	DIM. A.
2"	7-1/2"	16"	16-1/4"	2-1/4"	17-1/2"
3"	9"	19-1/2"	19-3/4"	2-1/2"	21"
3"	10"	23"	23-1/4"	2-15/16"	24-1/2"

* PREFIX MAY BE "A" OR "T"
** SUFFIX LETTER MAY BE A - Z

