
MEMORANDUM

To: FILE

From: Shukria Wiar

Subject: Application ID: 2016-099

Date: 7/21/2016

Comments Submitted by: Craig Messinger/Fire on 7/13/2016

We will consider this "New Construction" and say that both buildings will require NFPA 13R systems and will require local smoke and Carbon Monoxide protection in all the units.