

Bayside Employee Health Phone: Contractor Name: Address: ** HE Callahan Construction Co Turner Rd, P.O. Box 677 Auburn ME 04212 784-6927 **COST OF WORK:** PERMIT FEE: Proposed Use: Past Use: Doctor's Office 15,000 Same 95.00 FIRE DEPT. Approved INSPECTION: Use Group: B Type: 3B ☐ Denied Signature: Proposed Project Description: PEDESTRIAN ACTIVITIES DISTRICT Action: Approved Approved with Conditions: Relocate several walls, additional casework ☐ Shoreland Denied & new flooring throughout □Wetland ☐ Flood Zone □ Subdivision Signature: Date: ☐ Site Plan mai ☐minor ☐mm ☐ Permit Taken By: Date Applied For: MG February 25, 1999 **Zoning Appeal** □ Variance This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules. ☐ Miscellaneous Building permits do not include plumbing, septic or electrical work. 2. □ Conditional Use Building permits are void if work is not started within six (6) months of the date of issuance. False informa-☐ Interpretation ☐ Approved tion may invalidate a building permit and stop all work... □ Denied Historic Preservation Not in District or Landmark ☐ Does Not Require Review ☐ Requires Review Action: CERTIFICATION □Appoved I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been ☐ Approved with Conditions □ Denied authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all Date: areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit February 25, 1999 ADDRESS: PHONE: SIGNATURE OF APPLICANT DATE: RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE: **CEO DISTRICT**

COMMENTS

3/9/99 Preconstruction La	phone Dave Shelton discussed	2
FD Contact		
3/16/99 Work Completed	Final OK (DC)	
V		
3/24/00 de 78/5mg		
3/24/00 de 7/Jones		
Check with Fire Dopt Defore close of t 2-22-00 Mac - 15 This all Get?		
Check why		
Fine Don't What		
pluse lofet		
1,7-00		
Mac - 15 This all Set!		
× land		
	Inspection Record	
	Туре	Date
	Foundation:	
	Framing:	
	Plumbing:	
	Final:Other:	
	· · · · · · · · · · · · · · · · · · ·	

	BUILDING PERMIT REPORT
D.	ATE: 2 MAYCh 1999 ADDRESS: 323 MAYGING/ Way CBL \$23-E-002
	EASON FOR PERMIT: 10 Terior renovation 5
	JILDING OWNER: So. MAINE ProperTies
cc	ONTRACTOR: H. E. Callahan Const.
PE	RMIT APPLICANT: ·
	BE GROUPBBOCA 1996 CONSTRUCTION TYPE_3B
	CONDITION(S) OF APPROVAL
Th	is Permit is being issued with the understanding that the following conditions are met:
	proved with the following conditions: 4/8/7×20 +24 ×26 ×27 ×36 ×31, 18/9, 32
—	
¥ 1. 2.	This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be
2.5	obtained. (A 24 hour notice is required prior to inspection) Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more
2.5	than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside
	edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the
	floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with
	an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be
	higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane
	material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6"
	of the same material. Section 1813.5.2
2.6	Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of
	foundation and a maximum 6 'o.c. between bolts. (Section 2305.17)
3.	Precaution must be taken to protect concrete from freezing. Section 1908.0
4.	It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to
_	verify that the proper setbacks are maintained.
5.	Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting
	rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior
	spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board
	or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6.	All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National
0.	Mechanical Code/1993). Chapter 12 & NFPA 211
7.	Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's
• • •	building code.
(8.)	Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking
	surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum
	height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and
	public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a
	diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
	(Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".)
	Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections
	1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
9.	Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
10.	Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum
	11" tread. 7" maximum rise. (Section 1014.0)
11.	The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8") 1014.4

Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or The units must be operable from the inside without the use of special

12.

knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)

- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
- All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self 14. closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
- 16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2

A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0

The Fire Alarm System shall be maintained to NFPA #72 Standard.

The Sprinkler System shall maintained to NFPA #13 Standard.

All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)

- Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate 21. or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a 22. certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)
- All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
 - All requirements must be met before a final Certificate of Occupancy is issued.
- All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
- Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
 - Please read and implement the attached Land Use-Zoning report requirements.
 - 28. 29. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.3. of the City's building
- Glass and glazing shall meet the requirements of Chapter 24 of the building code.

This permit does not authorize The removal of any bearing walls.

Fire alorm system shall be my steined to ADA Standarde as required by the State Fire Morshilli office.

33.

appropriates, Building Inspector

y Wil cc: Lt: McDougall, PRO

Marge Schmuckal, Zoning Administrator

PSH 8-1-98

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application Attached Single Family Dwellings/Two-Family Dwelling Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building):			CHND	1110000
Total Square Footage of Proposed Structure EXISTING	<u> </u>	Square Footage of	fascp space :	4430 SF
Tax Assessor's Chart, Block & Lot Number Chart# 023 Block# E Lot# 002	Owner: So	. MAINF PROPERTIES	Telephone#:	
Owner's Address:	Lessee/BAYSIDE	Employee Hencity	Cost Of Work: \$ 15,000	\$ 95
Proposed Project Description: (Please be as specific as possible)		SEUGRAL WALLS,	Additional	Casework
Contractor's Name, Address & Telephone HE CALLAY TURNER Rd,	P.O.Box	677 AUBURN, ME C	927	Rec'd By
Current Use: Wocco Pico Doctor's OFFI	<u></u>	Proposed Use: DOCTORS OF	CCI C	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
•All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.

•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code. You must Include the following with you application:

1) ACopy of Your Deed or Purchase and Sale Agreement
2) A Copy of your Construction Contract, if available
3) A Plot Plan/Site Plan

3) A Plot Plan/Site Plan

Il be required for the above proposed projects. The attached

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a regist A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory struction)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing

• Electrical and plumbing layout. Mechanical drawings for any specialized equipment such the first establishment (air handling) or other types of work that may require special review must be included.

Certification

FEB 25 1999

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

emorec are	NOVISIONS OF the codes applicable to this perilin			
Signature	Mapplicant: E. Shell	H. E. CALLAHAN	Date: 2-25-99	
_	Building Permit Fee: \$25.00 for	the 1st \$1000.cost plus \$5.00 per \$1,	000.00 construction cost thereafter.	

Additional Site review and related fees are attached on a separate addendum

SEND TO COMPARTOR

