

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

May 22, 2017

Responsible Party 1: CF EAST BAYSIDE LLC 42 MARKET ST PORTLAND, ME 04101		Empire Beauty School 319 Marginal Way Portland ME 04101
Location 319 MARGINAL WAY	CBL 023 E002001	Inspection Date 5/12/2017
Inspector Alan Greene	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 6/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 39.2.9.1 EMERGENCY LIGHTS REQUIRED - 3 OR MORE STORIES; Emergency lighting shall be provided in accordance with Section 7.9 in any building where any one of the following conditions exist: 1. The building is three or more stories in height 2. The occupancy is subject to 100 or more occupants above or below the level of exit discharge 3. The occupancy is subject to 1,000 or more total occupants Rear Stairwell 2nd floor.	
NFPA 101- 39.2.10 EXIT SIGNS REQUIRED; Means of egress shall have signs in accordance with Section 7.10. Several exit lights need batteries replaced, will not light when tested.	
FINAL DATE OF COMPLETED VIOLATION(S)	___/___/___
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date

Responsible Party

Date

Responsible Party

SEEN AND AGREED

Date

Fire Prevention Bureau