

# CUNNINGHAM

## Security Systems

10 Princes Point Road • Yarmouth, Maine 04096  
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

October 16, 2013


Attn: Captain Christopher Pirone  
Fire Prevention Bureau  
Portland Fire Department  
380 Congress Street  
Portland, ME 04101  
Fax#: (207) 874-8410

Dear Captain Pirone,

This letter is to inform you that on October 16, 2013, we completed the installation, programming and testing of the new fire alarm devices added to the existing fire alarm control panel located at Coffee By Design, 1-11 Diamond, Portland, ME. These new devices were installed, programmed and test to NFPA 72 standards with signals sent to and received at our central monitoring station. These new devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File