



RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	7/5/2013


 10 Princes Point Road, Yarmouth, Maine 04096
 Office: 207.846.3350 • Fax: 207.846.6080

COFFEE BY DESIGN
DIAMOND ST. WAREHOUSE RENOVATION
1-11 DIAMOND ST., PORTLAND, ME
FIRE ALARM PLAN

DRAWN: JRB/JOB #13145
 CHECKED: WAYNE B. HAWES
 DATE: 7/3/2013
 REVISION: 0
 SCALE: 1/8"=1'-0"

FA-2

SHEET NOTES:
 ▷ ADDRESSABLE MONITOR NOTIFICATIONS PROVIDED TO MONITOR ALL WATER FLOW TAMPERS SWITCHES, AIR TAMPERS, PRE-AND POST INDICATOR TANKS, ESSENTIAL WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

