

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	7/5/2013


**CUNNINGHAM**  
**Security Systems**  
 10 Princess Point Road, Yarmouth, Maine 04096  
 Office: 207.846.3350 • Fax: 207.846.6080

**COFFEE BY DESIGN**  
**DIAMOND ST. WAREHOUSE RENOVATION**  
**1-11 DIAMOND ST., PORTLAND, ME**  
**FIRE ALARM PLAN**

DRAWN	JPB	UNICAD JOB #13345
CHECKED	WAYNE B. HAWS	NICET # 90496
DATE	7/3/2013	
REVISION	0	
SCALE	1/8"=1'-0"	

**FA-2**

**SHEET NOTES:**  
 ◆ ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, TAMPER SWITCHES, AIR, TEMPERATURE, AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).



UNICAD INC.  
 1000 W. 4600 St.  
 Portland, ME 04115  
 Office: 601.869.0410  
 www.unicad.net Fire Alarm Design & Drafting Services