



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)
Drawing : PORTLAND
Location : 126 NORTH BOYD STREET
Remote Area : #1 WET
Contract : 062016-1
Data File : TIRE STORAGE AREA CALC.WXF

Hydraulic Design Information Sheet

Name - TIRE WAREHOUSE PORTLAND Date - 10/25/16
Location - 126 NORTH BOYD STREET
Building - PORTLAND System No. - #1 WET
Contractor - HIGH TECH FIRE PROTECTION Contract No. - 062016-1
Calculated By - ED POULIN Drawing No. - FP-01
Construction: (X) Combustible () Non-Combustible Ceiling Height - 15'
Occupancy - TIRE STORAGE UP TO 25'

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve

S Other CHAPTER 18

T Specific Ruling Made By Date

M	Area of Sprinkler Operation - 1024	Density -	System Type (X) Wet	Sprinkler/Nozzle Make TYCO
D	Area Per Sprinkler - 80		() Dry	Model K17
E	Elevation at Highest Outlet - 15		() Deluge	Size 3/4"
S	Hose Allowance - Inside - N/A		() Preaction	K-Factor 16.8
I	Rack Sprinkler Allowance - N/A		() Other	Temp.Rat.155
G	Hose Allowance - Outside - 500		HEAD SPEC PER TABLE	18.4C

N Note

Calculation Flow Required - 2001 Press Required - 70
Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 5-18-16		Cap. -
T	Time of Test - 1:40 PM	Rated Cap.-	Elev.-
E	Static Press - 105	@ Press -	
R	Residual Press - 101	Elev. -	Well
S	Flow - 1443		Proof Flow
U	Elevation - 2		

P Location - HYDRANT DIRECTLY IN FRONT OF BUILDING AND CORNER OF BOYD.

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity TIRES STORED UP TO 25'	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled 20 %	Palletized 80 %	Rack
M	(X) Single Row () Conven. Pallet () Auto. Storage () Encap.		
S	(X) Double Row () Slave Pallet () Solid Shelf () Non		
T	() Mult. Row () Open Shelf		

R K Flue Spacing Clearance:Storage to Ceiling 36"
A Longitudinal Transverse

G Horizontal Barriers Provided:


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 2
Date 10/25/16

City Water Supply:
C1 - Static Pressure : 105
C2 - Residual Pressure: 101
C2 - Residual Flow : 1443

Demand:
D1 - Elevation : 5.197
D2 - System Flow : 1500.77
D2 - System Pressure : 69.221
Hose (Demand) : 500
D3 - System Demand : 2000.77
Safety Margin : 28.457



Fittings Used Summary

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 3
Date 10/25/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 4
Date 10/25/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
AA	13.0		37.65	na				
104	14.0		35.18	na				
105	14.0	16.8	35.06	na	99.48	0.001	80	35.0
106	14.0	16.8	35.0	na	99.39	0.001	80	35.0
107	14.0	16.8	35.43	na	100.0	0.001	80	35.0
108	14.0		37.86	na				
AB	13.0		37.68	na				
114	14.0		35.22	na				
115	14.0	16.8	35.1	na	99.53	0.001	80	35.0
116	14.0	16.8	35.04	na	99.45	0.001	80	35.0
117	14.0	16.8	35.48	na	100.06	0.001	80	35.0
118	14.0		37.91	na				
AC	13.0		37.78	na				
124	14.0		35.33	na				
125	14.0	16.8	35.22	na	99.7	0.001	80	35.0
126	14.0	16.8	35.16	na	99.61	0.001	80	35.0
127	14.0	16.8	35.6	na	100.24	0.001	80	35.0
128	14.0		38.07	na				
AD	13.0		38.04	na				
134	14.0		35.62	na				
135	14.0	16.8	35.51	na	100.11	0.001	80	35.0
136	14.0	16.8	35.46	na	100.04	0.001	80	35.0
137	14.0	16.8	35.93	na	100.7	0.001	80	35.0
138	14.0		38.46	na				
AE	13.0		38.35	na				
144	14.0		35.98	na				
145	14.0	16.8	35.87	na	100.62	0.001	80	35.0
146	14.0	16.8	35.83	na	100.56	0.001	80	35.0
147	14.0	16.8	36.33	na	101.26	0.001	80	35.0
148	14.0		38.94	na				
AF	13.0		39.0	na				
154	14.0		39.88	na				
158	14.0		42.31	na				
AG	13.0		39.34	na				
164	14.0		40.43	na				
168	14.0		43.23	na				
AH	13.0		39.64	na				
174	14.0		41.15	na				
178	14.0		44.74	na				
AI	13.0		39.76	na				
184	14.0		41.68	na				
188	14.0		46.02	na				
AJ	13.0		39.81	na				
194	14.0		42.47	na				
198	14.0		48.16	na				
BA	13.0		41.22	na				
BB	13.0		41.28	na				
BC	13.0		41.47	na				
BD	13.0		41.94	na				
BE	13.0		42.53	na				
BF	13.0		43.77	na				
BG	13.0		44.86	na				
BH	13.0		46.69	na				
BI	13.0		48.3	na				
BJ	13.0		51.01	na				
TOR	15.5		53.56	na				
FLW	5.0		59.46	na				
BOR	2.0		61.88	na				
H1	2.0		65.9	na				
HOSE	0.0		67.58	na	500.0			
TEST	2.0		69.22	na				

The maximum velocity is 30.25 and it occurs in the pipe between nodes BI and BJ

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 5
Date 10/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
AA	-125.20	2.157	1V 4.307	1.000	37.649				
to 104	-125.2	120.0 -0.1157	1T 12.307	16.614	-0.433				
				17.614	-2.038		Vel = 10.99		
104	0.0	2.157	0.0	1.000	35.178				
to 105	-125.2	120.0 -0.1160	0.0	0.0	0.0				
				1.000	-0.116		Vel = 10.99		
105	99.48	2.157	0.0	10.000	35.062				
to 106	-25.72	120.0 -0.0062	0.0	0.0	0.0				
				10.000	-0.062		Vel = 2.26		
106	99.39	2.157	0.0	10.000	35.000				
to 107	73.67	120.0 0.0434	0.0	0.0	0.0				
				10.000	0.434		Vel = 6.47		
107	100.00	2.157	1X 10.461	1.000	35.434				
to 108	173.67	120.0 0.2119	0.0	10.461	0.0				
				11.461	2.429		Vel = 15.25		
108	0.0	2.157	1T 12.307	1.500	37.863				
to BA	173.67	120.0 0.2120	0.0	12.307	0.433				
				13.807	2.927		Vel = 15.25		
	0.0								
	173.67				41.223		K Factor = 27.05		
AB	-125.04	2.157	1V 4.307	1.000	37.683				
to 114	-125.04	120.0 -0.1155	1T 12.307	16.614	-0.433				
				17.614	-2.034		Vel = 10.98		
114	0.0	2.157	0.0	1.000	35.216				
to 115	-125.04	120.0 -0.1150	0.0	0.0	0.0				
				1.000	-0.115		Vel = 10.98		
115	99.53	2.157	0.0	10.000	35.101				
to 116	-25.51	120.0 -0.0061	0.0	0.0	0.0				
				10.000	-0.061		Vel = 2.24		
116	99.45	2.157	0.0	10.000	35.040				
to 117	73.94	120.0 0.0436	0.0	0.0	0.0				
				10.000	0.436		Vel = 6.49		
117	100.06	2.157	1X 10.461	1.000	35.476				
to 118	174.0	120.0 0.2128	0.0	10.461	0.0				
				11.461	2.439		Vel = 15.28		
118	0.0	2.157	1T 12.307	1.500	37.915				
to BB	174.0	120.0 0.2127	0.0	12.307	0.433				
				13.807	2.937		Vel = 15.28		
	0.0								
	174.00				41.285		K Factor = 27.08		
AC	-124.56	2.157	1V 4.307	1.000	37.782				
to 124	-124.56	120.0 -0.1146	1T 12.307	16.614	-0.433				
				17.614	-2.018		Vel = 10.94		
124	0.0	2.157	0.0	1.000	35.331				
to 125	-124.56	120.0 -0.1150	0.0	0.0	0.0				
				1.000	-0.115		Vel = 10.94		
125	99.70	2.157	0.0	10.000	35.216				
to 126	-24.86	120.0 -0.0058	0.0	0.0	0.0				
				10.000	-0.058		Vel = 2.18		

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 6
Date 10/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
126	99.61	2.157		0.0	10.000	35.158			K Factor = 16.80	
to		120.0		0.0	0.0	0.0				
127	74.75	0.0445		0.0	10.000	0.445			Vel = 6.56	
127	100.24	2.157	1X	10.461	1.000	35.603			K Factor = 16.80	
to		120.0		0.0	10.461	0.0				
128	174.99	0.2150		0.0	11.461	2.464			Vel = 15.36	
128	0.0	2.157	1T	12.307	1.500	38.067				
to		120.0		0.0	12.307	0.433				
BC	174.99	0.2150		0.0	13.807	2.969			Vel = 15.36	
	0.0									
	174.99					41.469			K Factor = 27.17	
AD	-123.31	2.157	1V	4.307	1.000	38.038				
to		120.0	1T	12.307	16.614	-0.433				
134	-123.31	-0.1125		0.0	17.614	-1.981			Vel = 10.83	
134	0.0	2.157		0.0	1.000	35.624				
to		120.0		0.0	0.0	0.0				
135	-123.31	-0.1130		0.0	1.000	-0.113			Vel = 10.83	
135	100.12	2.157		0.0	10.000	35.511			K Factor = 16.80	
to		120.0		0.0	0.0	0.0				
136	-23.19	-0.0051		0.0	10.000	-0.051			Vel = 2.04	
136	100.04	2.157		0.0	10.000	35.460			K Factor = 16.80	
to		120.0		0.0	0.0	0.0				
137	76.85	0.0469		0.0	10.000	0.469			Vel = 6.75	
137	100.70	2.157	1X	10.461	1.000	35.929			K Factor = 16.80	
to		120.0		0.0	10.461	0.0				
138	177.55	0.2208		0.0	11.461	2.531			Vel = 15.59	
138	0.0	2.157	1T	12.307	1.500	38.460				
to		120.0		0.0	12.307	0.433				
BD	177.55	0.2208		0.0	13.807	3.049			Vel = 15.59	
	0.0									
	177.55					41.942			K Factor = 27.42	
AE	-121.72	2.157	1V	4.307	1.000	38.350				
to		120.0	1T	12.307	16.614	-0.433				
144	-121.72	-0.1099		0.0	17.614	-1.935			Vel = 10.69	
144	0.0	2.157		0.0	1.000	35.982				
to		120.0		0.0	0.0	0.0				
145	-121.72	-0.1100		0.0	1.000	-0.110			Vel = 10.69	
145	100.62	2.157		0.0	10.000	35.872			K Factor = 16.80	
to		120.0		0.0	0.0	0.0				
146	-21.1	-0.0043		0.0	10.000	-0.043			Vel = 1.85	
146	100.56	2.157		0.0	10.000	35.829			K Factor = 16.80	
to		120.0		0.0	0.0	0.0				
147	79.46	0.0499		0.0	10.000	0.499			Vel = 6.98	
147	101.26	2.157	1X	10.461	1.000	36.328			K Factor = 16.80	
to		120.0		0.0	10.461	0.0				
148	180.72	0.2282		0.0	11.461	2.615			Vel = 15.87	
148	0.0	2.157	1T	12.307	1.500	38.943				
to		120.0		0.0	12.307	0.433				
BE	180.72	0.2281		0.0	13.807	3.150			Vel = 15.87	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 7
Date 10/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 180.72					42.526		K Factor = 27.71	
AF to 154	98.82	2.157 120.0	1V 1T	4.307 12.307	1.000 16.614	38.999 -0.433			
	98.82	0.0747		0.0	17.614	1.315		Vel = 8.68	
154 to 158	0.0	2.157 120.0	1X	10.461 0.0	22.000 10.461	39.881 0.0			
	98.82	0.0747		0.0	32.461	2.425		Vel = 8.68	
158 to BF	0.0	2.157 120.0	1T	12.307 0.0	1.500 12.307	42.306 0.433			
	98.82	0.0747		0.0	13.807	1.031		Vel = 8.68	
	0.0 98.82					43.770		K Factor = 14.94	
AG to 164	106.93	2.157 120.0	1V 1T	4.307 12.307	1.000 16.614	39.337 -0.433			
	106.93	0.0864		0.0	17.614	1.522		Vel = 9.39	
164 to 168	0.0	2.157 120.0	1X	10.461 0.0	22.000 10.461	40.426 0.0			
	106.93	0.0864		0.0	32.461	2.806		Vel = 9.39	
168 to BG	0.0	2.157 120.0	1T	12.307 0.0	1.500 12.307	43.232 0.433			
	106.93	0.0864		0.0	13.807	1.193		Vel = 9.39	
	0.0 106.93					44.858		K Factor = 15.97	
AH to 174	122.01	2.157 120.0	1V 1T	4.307 12.307	1.000 16.614	39.645 -0.433			
	122.01	0.1103		0.0	17.614	1.943		Vel = 10.71	
174 to 178	0.0	2.157 120.0	1X	10.461 0.0	22.000 10.461	41.155 0.0			
	122.01	0.1103		0.0	32.461	3.581		Vel = 10.71	
178 to BH	0.0	2.157 120.0	1T	12.307 0.0	1.500 12.307	44.736 0.433			
	122.01	0.1103		0.0	13.807	1.523		Vel = 10.71	
	0.0 122.01					46.692		K Factor = 17.86	
AI to 184	135.33	2.157 120.0	1V 1T	4.307 12.307	1.000 16.614	39.761 -0.433			
	135.33	0.1336		0.0	17.614	2.353		Vel = 11.88	
184 to 188	0.0	2.157 120.0	1X	10.461 0.0	22.000 10.461	41.681 0.0			
	135.33	0.1336		0.0	32.461	4.337		Vel = 11.88	
188 to BI	0.0	2.157 120.0	1T	12.307 0.0	1.500 12.307	46.018 0.433			
	135.33	0.1336		0.0	13.807	1.845		Vel = 11.88	
	0.0 135.33					48.296		K Factor = 19.47	
AJ to 194	156.74	2.157 120.0	1V 1T	4.307 12.307	1.000 16.614	39.812 -0.433			
	156.74	0.1753		0.0	17.614	3.088		Vel = 13.76	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 8
Date 10/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
194 to 198	0.0 156.74	2.157 120.0 0.1753	1X 0.0	10.461 0.0	22.000 10.461 32.461	42.467 0.0 5.692		Vel = 13.76	
198 to BJ	0.0 156.74	2.157 120.0 0.1753	1T 0.0	12.307 0.0	1.500 12.307 13.807	48.159 0.433 2.421		Vel = 13.76	
	0.0 156.74					51.013		K Factor = 21.95	
AA to AB	125.20 125.2	4.26 120.0 0.0042	0.0 0.0	8.000 0.0	8.000 0.0	37.649 0.0 0.034		Vel = 2.82	
AB to AC	125.04 250.24	4.26 120.0 0.0150	0.0 0.0	6.600 0.0	6.600 0.0	37.683 0.0 0.099		Vel = 5.63	
AC to AD	124.56 374.8	4.26 120.0 0.0320	0.0 0.0	8.000 0.0	8.000 0.0	37.782 0.0 0.256		Vel = 8.44	
AD to AE	123.31 498.11	4.26 120.0 0.0543	0.0 0.0	5.750 0.0	5.750 0.0	38.038 0.0 0.312		Vel = 11.21	
AE to AF	121.72 619.83	4.26 120.0 0.0811	0.0 0.0	8.000 0.0	8.000 0.0	38.350 0.0 0.649		Vel = 13.95	
AF to AG	-98.82 521.01	4.26 120.0 0.0588	0.0 0.0	5.750 0.0	5.750 0.0	38.999 0.0 0.338		Vel = 11.73	
AG to AH	-106.93 414.08	4.26 120.0 0.0385	0.0 0.0	8.000 0.0	8.000 0.0	39.337 0.0 0.308		Vel = 9.32	
AH to AI	-122.01 292.07	4.26 120.0 0.0202	0.0 0.0	5.750 0.0	5.750 0.0	39.645 0.0 0.116		Vel = 6.57	
AI to AJ	-135.33 156.74	4.26 120.0 0.0064	0.0 0.0	8.000 0.0	8.000 0.0	39.761 0.0 0.051		Vel = 3.53	
	0.0 156.74					39.812		K Factor = 24.84	
BA to BB	173.67 173.67	4.26 120.0 0.0078	0.0 0.0	8.000 0.0	8.000 0.0	41.223 0.0 0.062		Vel = 3.91	
BB to BC	174.00 347.67	4.26 120.0 0.0279	0.0 0.0	6.600 0.0	6.600 0.0	41.285 0.0 0.184		Vel = 7.83	
BC to BD	175.00 522.67	4.26 120.0 0.0591	0.0 0.0	8.000 0.0	8.000 0.0	41.469 0.0 0.473		Vel = 11.77	
BD to BE	177.55 700.22	4.26 120.0 0.1016	0.0 0.0	5.750 0.0	5.750 0.0	41.942 0.0 0.584		Vel = 15.76	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
TIRE WAREHOUSE PORTLAND NORTH BOYD STREET (TIRE STORAGE AREA)

Page 9
Date 10/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BE	180.71	4.26		0.0	8.000	42.526				
to		120.0		0.0	0.0	0.0				
BF	880.93	0.1555		0.0	8.000	1.244		Vel = 19.83		
BF	98.82	4.26		0.0	5.750	43.770				
to		120.0		0.0	0.0	0.0				
BG	979.75	0.1892		0.0	5.750	1.088		Vel = 22.05		
BG	106.93	4.26		0.0	8.000	44.858				
to		120.0		0.0	0.0	0.0				
BH	1086.68	0.2292		0.0	8.000	1.834		Vel = 24.46		
BH	122.01	4.26		0.0	5.750	46.692				
to		120.0		0.0	0.0	0.0				
BI	1208.69	0.2790		0.0	5.750	1.604		Vel = 27.21		
BI	135.33	4.26		0.0	8.000	48.296				
to		120.0		0.0	0.0	0.0				
BJ	1344.02	0.3396		0.0	8.000	2.717		Vel = 30.25		
	0.0									
	1344.02					51.013		K Factor = 188.18		
BJ	1500.77	6.357	2V	25.147	36.000	51.013				
to		120.0		0.0	25.147	-1.083				
TOR	1500.77	0.0593		0.0	61.147	3.626		Vel = 15.17		
TOR	0.0	6.357	1Fsp	0.0	6.000	53.556				
to		120.0		0.0	0.0	5.548		* Fixed loss = 1		
FLW	1500.77	0.0592		0.0	6.000	0.355		Vel = 15.17		
FLW	0.0	6.357	1Zib	0.0	2.000	59.459				
to		120.0		0.0	0.0	2.299		* Fixed loss = 1		
BOR	1500.77	0.0595		0.0	2.000	0.119		Vel = 15.17		
BOR	0.0	6.16	1G	4.304	10.000	61.877				
to		140.0	1T	43.037	67.425	0.0				
H1	1500.77	0.0520	1E	20.084	77.425	4.024		Vel = 16.16		
H1	0.0	8.27	1T	55.354	10.000	65.901				
to		140.0		0.0	55.354	0.866				
HOSE	1500.77	0.0124		0.0	65.354	0.809		Vel = 8.96		
HOSE	500.00	6.16	1G	4.304	4.000	67.576		Qa = 500		
to		140.0	1E	20.084	24.388	-0.866				
TEST	2000.77	0.0885		0.0	28.388	2.511		Vel = 21.54		
	0.0									
	2000.77					69.221		K Factor = 240.48		