

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit 06-1294	024 D001001
-------------------	-------------

Location of Construction: 160 FOX ST	Owner Name: FRANKLIN & SOMERSET PORT	Owner Address: 550 BOWIE ST	Phone:
Business Name:	Contractor Name: Merrimack Valley Corp	Contractor Address: 20 Aegean Dr. Unit #11 Methuen	Phone 19786890224
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone: B7

Past Use: Commercial - Whole Foods	Proposed Use: Commercial install heating cooling systems roof/ attic. Installing 8-10 Commercial Kitchen Hood Systems.
---------------------------------------	---

Permit Fee: \$4,710.00	Cost of Work: \$469,071.00	CEO District: 1
---------------------------	-------------------------------	--------------------


FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied NFPA 96	INSPECTION: Use Group M Type H/A IMC 7003
--	---

Install heating cooling systems roof/ attic & Kitchen Hoods.

Signature *[Signature]* Signature *[Signature]*
 PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)
 Action: Approved Approved w/Conditions Denied
 Signature: _____ Date: _____

Permit Taken By: dmartin	Date Applied For: 08/30/2006	Zoning Approval
-----------------------------	---------------------------------	------------------------

Special Zone or Reviews	Zoning Appeal	Historic Preservation
<input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>	<input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date: _____	<input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied <i>AGM</i> Date: _____




CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 2 Somerset Street Use of Building Commercial Date 08.29.06
 Name and address of owner of appliance Whole Foods Market - North Atlantic Regional Office
125 Cambridge Park Drive - Cambridge Mass. 02140
 Installer's name and address MERRIMACK Valley Corporation - 20 Argosian Drive Unit #11
Mathuen Mass. 01844 Telephone 978 689 0224

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name:

Heating / Cooling Units

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF **NO** Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # _____
- other HVAC - no plumbing

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ uL# _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank _____

Number of Tanks _____

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ 469 071.⁰⁰

Permit Fee: \$ 4110.⁰⁰


Approved

Approved with Conditions

Fire: _____

Ele.: _____

Bldg.: _____



See attached letter or requirement

Inspector's Signature _____

Date Approved 09/06/06

Signature of Installer [Signature]

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-1294	Date Applied For: 08/30/2006	CBL: 024 D001001
------------------------------	--	----------------------------

Location of Construction: 160 FOX ST	Owner Name: FRANKLIN & SOMERSET PORT	Owner Address: 550 BOWIE ST	Phone:
Business Name:	Contractor Name: Merrimack Valley Corp	Contractor Address: 20 Aegean Dr. Unit # 11 Methuen	Phone (978) 689-0224
	Phone:	Permit Type: HVAC	

Commercial install heating cooling systems roof/ attic. Installing 8-10 Commercial Kitchen Hood Systems.	Install heating cooling systems roof/ attic & Kitchen Hoods.
--	--

Dept: Zoning **Status:** Approved with Conditions **Reviewer:** Ann Machado **Approval Date:** 09/12/2006

Note: **OktoIssue:**

- 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building **Status:** Approved with Conditions **Reviewer:** Michael A. Collins **Approval Date:** 09/08/2006

Note: Recieved on 09/08/06. Review in progress. **OktoIssue:**

- 1) The installation must comply with the State of Maine Gas Regulations.
- 2) Must be installed in compliance with NFPA 96.
- 3) Equipment must be installed in compliance with the manufacturer's specifications
- 4) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules
- 5) Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approval prior to work
- 6) Separate permits are required for any electrical, plumbing, or HVAC systems
Separate plans may need to be submitted for approval as a part of this process.

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 09/11/2006

Note: **OktoIssue:**

- 1) Install shall comply with NFPA 96. A compliance letter shall be required for each system.