GENERAL POWER NOTES:

1. REFER TO DRAWING E00.1 FOR LEGEND, SYMBOLS AND GENERAL NOTES.
2. REFER TO ARCHITECTURAL DRAWINGS FOR ASSOCIATED NOTES, MOUNTING DETAILS, HEIGHTS AND EXACT LOCATIONS OF ALL DEVICES.
3. CIRCUIT NUMBERS ARE DIAGRAMMATIC. EXACT NUMBERS SHALL BE DETERMINED IN THE FIELD AND REFLECTED ON AS-BUILT DOCUMENTATION BY THE ELECTRICAL CONTRACTOR. THE ASSOCIATED CIRCUIT NUMBERS THAT ARE APPLIED TO EACH DEVICE AND PIECE OF EQUIPMENT INFERS INTERCONNECTING BRANCH CIRCUITRY. INTERCONNECTING BRANCH WIRING SHALL BE SIZED EQUAL TO THE HOMERUN UNLESS NOTED OTHERWISE.
4. VOLTAGE DROP HAS BEEN CONSIDERED IN THE DESIGN OF ALL BRANCH CIRCUITRY AND FEEDER SIZES BASED UPON THE ILLUSTRATED EQUIPMENT LAYOUTS AND SHORTEST CONDUCTOR/RACEWAY ROUTING. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR DEVIATIONS TAKEN THAT WILL INCREASE CONDUCTOR/RACEWAY ROUTING LENGTHS. BRANCH CIRCUITS LONGER THAN 75' FOR 120V FROM PANEL TO LAST OUTLET SHALL BE INCREASED A MINIMUM OF ONE SIZE ABOVE THAT SPECIFIED TO LIMIT VOLTAGE DROP TO LESS THAN 3%. FEEDERS SHALL FOLLOW SIMILAR GUIDELINES AND BE LIMITED TO 2% DROP.
5. POWER BRANCH CIRCUITRY SHALL BE INSTALLED IN CONDUIT FROM THE PANEL TO THE FIRST DEVICE AND/OR WHERE EXPOSED. POWER BRANCH CIRCUITRY MAY BE TYPE MC CABLE WHERE CONCEALED ABOVE SUSPENDED CEILINGS AND IN METAL STUD WALLS.
6. MAINTAIN CONTINUITY OF BRANCH CIRCUITRY ASSOCIATED WITH ALL EXISTING POWER DEVICES TO REMAIN.
7. ALL ELECTRICAL EQUIPMENT IS EXISTING TO REMAIN UNLESS NOTED OTHERWISE.
8. REFER TO DRAWING E70.1 FOR ELECTRICAL EQUIPMENT SCHEDULE AND WIRING REQUIREMENTS.

HARRIMAN
AUBURN PORTLAND MANCHESTER

WHOLE FOODS MARKET

PUB DEVELOPMENT AND DEPARTMENT RELOCATIONS
2 SOMERSET ST
PORTLAND, ME

Harriman Project No.	15103

Key Plan — Proj North

PROFESSIONAL ELECTRICAL CONTRACTORS OF CT, INC.
100 Access Road
Norwood, MA 02062
phone 781-769-7767
fax 781-769-2911
145 Robert Jackson Way
Plainville, CT 06062

e3i Engineers Inc.
4 South Market Street,
Suite S5026
Boston, MA 02109
Tel 781 799 9351

Issues and Revisions

Mark	Date	Description
--	09-28-15	ISSUED FOR PERMITTING

STATE OF MAINE — DAVID J. COURTEMANCHE — No. 10536 — LICENSED PROFESSIONAL ENGINEER

Drawing Scales
1/8" = 1'-0"

0 4' 8' 12'

PA / PE: ***
Drawn By: ***

© 2015 Harriman Associates

ELECTRICAL FIRST FLOOR POWER PLAN

E30

Date: 12/23/15