



MINIMUM CONDUIT SIZE SHALL BE 3/4" RIGID CONDUIT. AND CITY. ALL CIRCUITS SHALL BE CLASS B LOOPS.

ELEVATOR PIT SHALL HAVE A SMOKE DETECTOR, AND A 135DEG. HEAT DETECTOR, THE HEAT DETECTOR SHALL BE LESS THAN 2' FROM SPRINKLER HEAD. COORDINATE EXACT QUANTITY AND LOCATION OF FIRE PROTECTION DEVICES WITH FIRE PROTECTION CONTRACTOR. PROVIDE SEPARATE MULTIPLEX LOOP INITIATING CIRCUIT PER FLOOR PROVIDE SEPARATE 24V POWER CIRCUIT FOR CONTROL ADDRESSABLE MODULES PER MANUFACTURER'S REQUIREMENTS.

## (TYPICAL).





