

B6	3#10,1#6, 3/4"C
D	3#6,1#8, 1"C
DD	4#6,1#8, 1"C
H	3#1, 1#6, 1-1/4"C
HH	4#1, 1#8, 1-1/2"C
KK	4#2/0,1#6, 1-1/2"C
M	3#4/0,1#4, 2-1/2"C
MM	4#4/0,1#4, 2-1/2"C
QQ	4#750kCMIL,1#1/0 4"C

ONE-LINE DIAGRAM - EXISTING

SCALE: NONE

Stantec

Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough, ME 04074-8929
Tel: (207) 883-3355 / Fax: (207) 883-3376
www.stantec.com

Reviewed for Code Compliance
Inspectional Services Division
Approved with Conditions
Date: 05/03/16

ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT 2016
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

PORTLAND GASTROENTEROLOGY CENTER

161 Marginal Way - Portland, Maine 04101

No.	Date	Description

Revision Schedule

STATE OF MAINE
RICHARD A. NADEAU
No. 10003
LICENSED
PROFESSIONAL ENGINEER
3/18/2016

JOB NO.
195210852

DRWN. MLC
CHK Checker

SCALE:

ISSUE
PERMIT SET
3/18/2016

TITLE
EXISTING ONE-LINES & RISERS

SHEET
E002