AMBULATORY CARE AREA 1 SMOKE COMPARTMENT.
REFER TO A003.
NEW CEILING AND FLOOR PLAN. REMOVE EXISTING SPRINKLER HEADS AND SELECT PIPING. DESIGN AND INSTALL NEW SPRINKLER LAYOUT PER NFPA 13 AND LOCAL CODES.

AMBULATORY CARE AREA 2 SMOKE COMPARTMENT.
REFER TO A003.
NEW CEILING AND FLOOR PLAN. REMOVE EXISTING SPRINKLER HEADS AND SELECT PIPING. DESIGN AND INSTALL NEW SPRINKLER LAYOUT PER NFPA 13 AND LOCAL CODES.

BUSINESS SMOKE COMPARTMENT.
REFER TO A003.
NEW CEILING AND FLOOR PLAN. REMOVE EXISTING SPRINKLER HEADS AND SELECT PIPING. DESIGN AND INSTALL NEW SPRINKLER LAYOUT PER NFPA 13 AND LOCAL CODES.

EXISTING 3" RISER

PLAN NORTH

1 FIRE PROTECTION LEVEL 4 NEW PLAN
3/16" = 1'-0"

0' 2' 4' 8'



PLAN NORTH

2 FIRE PROTECTION LEVEL 5 NEW PLAN
3/16" = 1'-0"

Stantec

Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough, ME 04074-8929
Tel: (207) 883-3355 / Fax: (207) 883-3376
www.stantec.com

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/03/16

ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT 2016
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

PORTLAND GASTROENTEROLOGY CENTER

161 Marginal Way - Portland, Maine 04101

No.	Date	Description
		Revision Schedule

STATE OF MAINE
CHRIS TUFFER M. PIIK
No. 10695
3-18-2016
LICENSED
PROFESSIONAL ENGINEER

JOB NO.
195210852

DRWN. CHK
ERD CMP

SCALE:

ISSUE
PERMIT SET
3/18/2016

TITLE
FIRE PROTECTION LEVEL 4 AND 5 NEW PLAN

SHEET
F102