

1 ELECTRICAL LIGHTING LEVEL 4 NEW PLAN
3/16" = 1'-0"

Lighting Control System:

The lighting controls designed to meet the control requirements as defined in the ASHRAE/IES 90.1-2007 energy standard.

The control system shall be programmable at a microprocessor-based central processing unit. The system shall provide weekly routine and annual holiday scheduling and automatically adjust for leap year and daylight savings time.

Provide lighting controls to automatically shut off building lighting in all spaces.
At 6:00 PM or hour as defined by tenant, the control system will blink several times, warning users that the common area lights will turn OFF in five minutes. At 6:05 PM, the control system will turn the common area lighting OFF. Users working afterhours may keep the lights ON, or turn the lights back ON, by toggling the manual wall switches, which function as a 120-minute override for the timeclock automatic shutoff system.

After 120 minutes, the system will blink the lights again, and sweep them OFF five minutes later unless the override is again activated.

The interior lighting controls will enact the following strategies intended to minimize energy consumption:

1) Common areas shall be control via a timeclock-based low-voltage control system via a central lighting control panel. Provide time schedules based on Portland Gastro's hours of operation and staff hours for 3rd and 4th floor.

2) Provide automatic shutoff via single load wall mounted occupancy sensors in small, enclosed offices and exam rooms.

3) Kitchenette areas, and multi-user offices shall have a ceiling mounted occupancy sensor and wall switch.

4) In presentation spaces, such as the conference and training rooms, the controls shall provide flexibility to enable users to select preset scenes light levels.

5) Each open office area shall be controlled by a combination of manual wall switches and timeclock schedule functionality residing in the low-voltage relay panel-based control system. Provide ceiling mounted occupancy sensors to maintain/override time schedule for staff on site after hours.

6) The following spaces have local diming controls for up to 3 zones, ceiling mounted occupancy sensor with scene switch: Reception 337, Training Room/Lounge 317, LG Conf. 304, Reception 411, Procedure Rooms 1-6, Pathology lab 400.

7) The following spaces have networked diming controls with 924 relays for up to 3 zones, with scene switch to set normal and emergency fixtures to 4 preset scenes and raise/ lower buttons: at Circulation corridors near patient Prep and Recovery C480 & C420.

Stantec
Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough, ME 04074-8929
Tel: (207) 883-3355 / Fax: (207) 883-3376
www.stantec.com

Reviewed for Code Compliance
Inspectional Services Division
Approved with Conditions
Date: 05/03/16

ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT 2016
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

PORTLAND GASTROENTEROLOGY CENTER

161 Marginal Way - Portland, Maine 04101

No.	Date	Description
Revision Schedule		

REGISTERED PROFESSIONAL ENGINEER
RICHARD A. NACCARATO
No. 10013
LICENSED
3/18/2016

JOB NO.
195210852

DRWN. MLC | CHK Checker

SCALE:

ISSUE
PERMIT SET
3/18/2016

TITLE
ELECTRICAL LIGHTING LEVEL 4 NEW PLAN

SHEET
EL102