

1 PLUMBING MEDICAL GAS LEVEL 4 NEW PLAN
3/16" = 1'-0"



2 LEVEL 1 KEY PLAN
3/64" = 1'-0"



3 PLUMBING MEDICAL GAS LEVEL 1 MEDICAL GAS ROOM PART PLAN
3/16" = 1'-0"



4 PLUMBING MEDICAL GAS LEVEL 1 VACUUM PUMP ROOM PART PLAN
3/16" = 1'-0"

Stantec

Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough, ME 04074-8929
Tel: (207) 883-3355 / Fax: (207) 883-3376
www.stantec.com

Reviewed for Code Compliance
Inspectional Services Division
Approved with Conditions
Date: 05/03/16

ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT 2016
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

PORTLAND GASTROENTEROLOGY CENTER
161 Marginal Way - Portland, Maine 04101

No.	Date	Description
Revision Schedule		

STATE OF MAINE
CHRISTOPHER M. PIIK
No. 10695
3-18-2016
LICENSED PROFESSIONAL ENGINEER

JOB NO.
195210852

DRWN. CHK
ERD CMP

SCALE:

ISSUE
PERMIT SET
3/18/2016

TITLE
PLUMBING MEDICAL GAS NEW PLANS

SHEET
P106