PLUMBING FIXTURE SCHEDULE

TAG		Description	CW CONNECTION SIZE	HW CONNECTION SIZE	WASTE CONNECTION SIZE	VENT CONNECTION SIZE	MANUFACTURER AND MODEL
FD	1	*FLOOR DRAIN			4"	2"	
P	1	*WATER CLOSET - WALL HUNG	1"		4"	2"	AMERICAN STANDARD MODEL 3351.101 WITH SLOAN MODEL 111-1.6 PROVIDE WITH 500 POUND CARRIER.
P	1A	*WATER CLOSET - WALL HUNG WITH BEDPAN LUGS & BEDPAN WASHER	1"		4"	2"	AMERICAN STANDARD MODEL 3352.101 WITH SLOAN MODEL BPW 1000-1.6. PROVIDE WITH 500 POUND CARRIER.
P	2	*LAVATORY - WALL HUNG - STAFF	1/2"	1/2"	1 1/2"	1 1/4"	KOHLER MODEL K-2035-1 WITH CHICAGO FAUCETS 116.870.AB.1
P	3	*LAVATORY - WALL HUNG - PATIENT	1/2"	1/2"	1 1/2"	1 1/4"	KOHLER MODEL K-2035-1 WITH CHICAGO FAUCETS 116.870.AB.1
P	4	*SHOWER	1/2"	1/2"	2"	1 1/2"	____SHOWER CONTROLS ONLY. ENCLOSURE BY OTHERS.
P	5	*SS SINK - COUNTER - EXAM ROOM	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL LRAD151765 WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	6	*SS SINK - COUNTER - CONF	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL ELUHAD141855 WITH DELTA MODEL 1958LF FAUCET
P	7	*SS SINK - COUNTER WITH EYEWASH - MED SUPPLY	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP AND GUARDIAN G1895-TMV. COORDINATE LEFT OR RIGHT HAND MOUNTING WITH ARCHITECTURAL DRAWINGS.
P	8	*SS SINK - COUNTER - LOUNGE	1/2"	1/2"	2"	1 1/2"	ELKAY MODEL LARAD221965 WITH ELKAY LKHA2031 AND INSINKERATOR MODEL EVOLUTION EXCEL DISPOSAL. PROVIDE 1/2" DHW VALVED CONNECTION FOR DISHWASHER.
P	8A	*SS SINK - COUNTER - KITCHEN	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL LRAD151765 WITH ELKAY LK792LSSS.
P	9	*SS SINK - COUNTER - NURSE	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	9A	*SS SINK - COUNTER WITH EYEWASH - NURSE	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP AND GUARDIAN G1895-TMV. COORDINATE LEFT OR RIGHT HAND MOUNTING WITH ARCHITECTURAL DRAWINGS.
P	10	*SS SINK - COUNTER WITH EYEWASH - INFUSION OFFICE	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL LRAD151765 WITH CHICAGO FAUCETS MODEL 116.432.AB.1 AND GUARDIAN G1895-TMV. COORDINATE LEFT OR RIGHT HAND MOUNTING WITH ARCHITECTURAL DRAWINGS.
P	11	*SS SINK - COUNTER WITH EYEWASH - PATH LAB W/ EYEWASH	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP AND GUARDIAN G1895-TMV. COORDINATE LEFT OR RIGHT HAND MOUNTING WITH ARCHITECTURAL DRAWINGS.
P	12	*SS SINK - COUNTER - PATH LAB	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	13	*SS SINK - COUNTER - PROCEDURE	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL LRAD191965 WITH CHICAGO FAUCETS MODEL 116.432.AB.1
P	14	*SS SINK - COUNTER - SOILED UTILITY	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	15	*SS SINK - COUNTER WITH EYEWASH - PHLEB	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP AND GUARDIAN G1895-TMV. COORDINATE LEFT OR RIGHT HAND MOUNTING WITH ARCHITECTURAL DRAWINGS.
P	16	*SINK - WALL HUNG WITH EYEWASH - SCOPE CLEAN	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP AND GUARDIAN G1814-BC-T-TMV
P	17	*SINK - WALL HUNG - PROCEDURE	1/2"	1/2"	1 1/2"	1 1/2"	ELKAY MODEL ELVWO22193 WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	18	*SINK - WALL HUNG - SOILED UTILITY	1"	1"	4"	2"	___WITH ___
P	19	*SINK - WALL HUNG - NURSE	1/2"	1/2"	1 1/2"	1 1/2"	___ WITH CHICAGO FAUCETS MODEL 895-317GN2AE36ABCP
P	20	*SINK - TRIPLE BASIN - SCOPE REPROCESS	1/2"	1/2"	2"	2"	___ WITH ___
P	21	*MOP SINK - CORNER	1/2"	1/2"	3"	2"	FIAT MODEL TSBC1610 WITH CHICAGO FAUCETS MODEL 540-LD897SWXFXKCP. PROVIDE WITH HOSE & HOSE BRACKET, STAINLESS STEEL WALL GUARDS
P	22	*WATER COOLER	1/2"		0"	0"	___ WITH ___



BARRIER FREE SHOWER SET-UP N.T.S.



CLEANOUT N.T.S.



NOTES:
1. CYLINDERS SHOWN SINGLE ROW 5X5 ARRANGEMENT FOR INFORMATIONAL PUROPOSES ONLY. DOUBLE ROW PERMITTED IF NEEDED. MAINTAIN 2" BETWEEN CYLINDERS. SEE FLOOR PLAN FOR MORE INFORMATION ON ARRANGEMENT AND QUANTITIES.
2. DETAIL TYPICAL FOR OXYGEN, NITROUS OXIDE, MEDICAL AIR AND NITROGEN MANIFOLDS. CYLINDER QUANTITY AS INDICATED ON DRAWINGS.
3. INSTALL SYSTEM IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS

TYPICAL MEDGAS MANIFOLD N.T.S.



BARRIER FREE FLUSH VALVE ORIENTATION N.T.S.



INDIRECT WASTE FUNNEL N.T.S.



MEDGAS VALVE BOX INSTALLATION N.T.S.



NOTE:
FLOOR DRAINS REQUIRE TRAP PRIMER. REFER TO TRAP PRIMER DETAIL ON THIS SHEET.

FLOOR DRAIN IN EXISTING FLOOR N.T.S.



FLOOR DRAIN W/ TRAP PRIMER N.T.S.

Stantec
Stantec Consulting Services Inc.
482 Payne Road Scarborough Court
Scarborough, ME 04074-8929
Tel: (207) 883-3355 / Fax: (207) 883-3376
www.stantec.com

Reviewed for Code Compliance
Inspection Services Division
Approved with Conditions
Date: 05/03/16

ARCHITECTS
49 DARTMOUTH STREET
PORTLAND, MAINE 04101
207-775-1059
www.pdtarchs.com

COPYRIGHT 2016
PDT Architects
Reuse or reproduction of the contents of this document is not permitted without written permission of PDT Architects.

PORTLAND GASTROENTEROLOGY CENTER

161 Marginal Way - Portland, Maine 04101

No.	Date	Description
Revision Schedule		

STATE OF MAINE
CHRISTOPHER M. PIIK
No. 10095
3-18-2016
LICENSED
PROFESSIONAL ENGINEER

JOB NO.
195210852

DRWN. CHK
ERD CMP

SCALE:

ISSUE
PERMIT SET
3/18/2016

TITLE
PLUMBING DETAILS AND SCHEDULES

SHEET
P501