Panel No: PG-MDP

Mains Rating: 600 A
A.I.C. Rating: 42kA
Volts: 480/277 Wye
Service: 3Phase,4Wires

Supply From:
Rating: 600 A

Location: LEVEL 3/ELECTRIC ROOM 353
Mounting: Surface
Mains Type: MLO
Enclosure: Indoor

Notes:

Wire Size	Conduit Size	Load Name	Trip	Poles	CKT	ØA	ØB	ØC	ØA	ØB	ØC	CKT	Poles	Trip	Load Name	Conduit Size	Wire Size
3-#250, 1-#250, 1-#6	3"	HP3	200 A	3	1	9060 VA			29910 VA			2	3	150 A	T3	2"	3-#3/0, 1-#3/0, 1-#6
--	--	--	--	--	3		3790 VA			27750 VA		4	--	--	--	--	--
--	--	--	--	--	5			3711 VA			26940 VA	6	--	--	--	--	--
3-#3/0, 1-#3/0, 1-#6	2"	T4	150 A	3	7	20360 VA			10321 VA			8	3	80 A	T3EM	1 1/2"	3-#3, 1-#3, 1-#8
--	--	--	--	--	9		24015 VA			9246 VA		10	--	--	--	--	--
--	--	--	--	--	11			23998 VA			9978 VA	12	--	--	--	--	--
3-#300, 1-#300, 1-#4		MECH - HVAC E1	225 A	3	13	44320 VA			15507 VA			14	3	125 A	MECH - HVAC 3	3/4"	3-#1/0, 1-#1/0, 1-#6
--	--	--	--	--	15		44320 VA			15507 VA		16	--	--	--	--	--
--	--	--	--	--	17			44320 VA			15507 VA	18	--	--	--	--	--
1-#12, 1-#12, 1-#12	3/4"	MECH - EF-5	20 A	1	19	828 VA			828 VA			20	1	20 A	MECH - EF-6	3/4"	1-#12, 1-#12, 1-#12
3-#12, 1-#12, 1-#12	3/4"	MECH - EF-7	20 A	3	21		373 VA					22					
--	--	--	--	--	23			373 VA				24					
--	--	--	--	--	25	373 VA						26					
					27							28					
					29							30					
					31							32					
					33							34					
					35							36					
					37							38					
					39							40					
					41							42					

Total Load:	131507 VA 125000 VA 124827 VA
Total Connected Load:	379657 VA
Total Conn. Current:	457 A
Total Est. Demand:	309557 VA
Total Est. Demand Current:	372 A

Notes:

Panel No: P3

Mains Rating: 200 A
A.I.C. Rating: 10kA
Volts: 120/208 Wye
Service: 3Phase,4Wires

Supply From: T3
MCB Rating: 200 A
(EXISTING)

Location: LEVEL 3/ELECTRIC ROOM 353
Mounting: Surface
Mains Type: MCB
Enclosure: Indoor

Notes:
FEED THROUGH LUGS

Wire Size	Conduit Size	Load Name	Trip	Poles	CKT	ØA	ØB	ØC	ØA	ØB	ØC	CKT	Poles	Trip	Load Name	Conduit Size	Wire Size
1-#12, 1-#12, 1-#12	3/4"	RECP EXAM 388	20 A	1	1	900 VA			1260 VA			2	1	20 A	RECP Room 369, C360		1-#10, 1-#10, 1-#10
1-#12, 1-#12, 1-#12	3/4"	RECP EXAM 367	20 A	1	3		720 VA			540 VA		4	1	20 A	RECP Room 370, 359, 358		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12	3/4"	RECP EXAM 366	20 A	1	5			720 VA			360 VA	6	1	20 A	RECP MED SUPPLY 371		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12	3/4"	RECP OFFICE-NP 365	20 A	1	7	540 VA			720 VA			8	1	20 A	RECP WORK 372		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12	3/4"	RECP OFFICE-NP 365	20 A	1	9		720 VA			900 VA		10	1	20 A	RECP EXAM-SN 374		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12	3/4"	RECP OFFICE-NP 365	20 A	1	11			540 VA			1080 VA	12	1	20 A	RECP C/O 361, 360		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 364	20 A	1	13	720 VA			900 VA			14	1	20 A	RECP OPEN WORK 380		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 363	20 A	1	15		720 VA			900 VA		16	1	20 A	RECP OPEN WORK 380		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 362	20 A	1	17			720 VA			900 VA	18	1	20 A	RECP OPEN WORK 380		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFFICE/ FUTURE EXAM 386	20 A	1	19	900 VA			1080 VA			20	1	20 A	RECP OPEN WORK 380		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 385	20 A	1	21		900 VA			720 VA		22	1	20 A	RECP OPEN WORK 380		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 384	20 A	1	23			900 VA			360 VA	24	1	20 A	RECP PRINT STATION 380A		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 383	20 A	1	25	900 VA			600 VA			26	1	20 A	PROJECTOR LOUNGE 317		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 382	20 A	1	27		900 VA			540 VA		28	1	20 A	RECP LOUNGE 317		1-#12, 1-#12, 1-#12
1-#10, 1-#10, 1-#10		RECP PROVIDER 381	20 A	1	29			900 VA			900 VA	30	1	20 A	RECP LOUNGE 317		1-#10, 1-#10, 1-#10
1-#12, 1-#12, 1-#12		MECH	20 A	1	31	150 VA			360 VA			32	1	20 A	RECP LOUNGE 317		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		MECH	20 A	1	33		250 VA			1440 VA		34	1	20 A	RECP - MICROWAVE LOUNGE 317		1-#10, 1-#10, 1-#10
1-#12, 1-#12, 1-#12		RECP CIRCULATION C350	20 A	1	35			180 VA			840 VA	36	1	20 A	RECP- FRIDGE LOUNGE 317		1-#12, 1-#12, 1-#12
--	--	Spare	20 A	1	37	0 VA			1440 VA			38	1	20 A	RECP - MICROWAVE LOUNGE 317	3/4"	1-#10, 1-#10, 1-#10
--	--	Spare	20 A	1	39		0 VA			800 VA		40	1	20 A	JBOX - DISHWASH LOUNGE 317	3/4"	1-#12, 1-#12, 1-#12
--	--	Spare	20 A	1	41			0 VA			1440 VA	42	1	20 A	RECP - MICROWAVE LOUNGE 317	3/4"	1-#10, 1-#10, 1-#10

Total Load:	10470 VA 10050 VA 9840 VA
Total Connected Load:	30360 VA
Total Conn. Current:	84 A
Total Est. Demand:	23660 VA
Total Est. Demand Current:	66 A

Notes:

Panel No: HP3

Mains Rating: 225 A
A.I.C. Rating: 42kA
Volts: 480/277 Wye
Service: 3Phase,4Wires

Supply From: PG-MDP
MCB Rating: 225 A
(EXISTING)

Location: LEVEL 3/ELECTRIC ROOM 353
Mounting: Surface
Mains Type: MLO
Enclosure: Indoor

Notes:

Wire Size	Conduit Size	Load Name	Trip	Poles	CKT	ØA	ØB	ØC	ØA	ØB	ØC	CKT	Poles	Trip	Load Name	Conduit Size	Wire Size
--	--	Spare	100 A	3	1	0 VA			342 VA			**2**	**1**	**20 A**	LTS Room C480, 480A, C420, C440		1-#12, 1-#12, 1-#12
--	--	--	--	--	3		0 VA			1998 VA		**4**	**1**	**20 A**	Room 408, 483, 406, 403-1, 445, 404, 404...		1-#6, 1-#6, 1-#6
--	--	--	--	--	5			0 VA			0 VA	**6**	**1**	**20 A**	LC3		1-#12, 1-#12, 1-#12
--	--	Spare	100 A	3	7	0 VA			460 VA			**8**	**1**	**20 A**	LTS TOILET/ SHOWER 456		1-#12, 1-#12, 1-#12
--	--	--	--	--	9		0 VA			78 VA		**10**	**1**	**20 A**	LTS ELEC 440		1-#12, 1-#12, 1-#12
--	--	--	--	--	11			0 VA				**12**					
1-#12, 1-#12, 1-#12		Room 381, 382, 386, 362, 363, 364, 365,...	**20 A**	**1**	**13**	767 VA			4072 VA			14	1	20 A	Room 433, 434, 435, 436, 437, 438, 439,...		1-#3, 1-#3, 1-#3
1-#10, 1-#10, 1-#10		LTS Room C310, C380, C300, C320, C330...	**20 A**	**1**	**15**		928 VA					16					
1-#8, 1-#8, 1-#8		Room 380, 320, C300, 306, 354, 361, 360,...	**20 A**	**1**	**17**			1376 VA			2335 VA	18	1	20 A	LTS Room C480, C440, C450, C400		1-#6, 1-#6, 1-#6
1-#12, 1-#12, 1-#12		LTS	20 A	1	19	19 VA			1481 VA			20	1	20 A	Room 329, 312, 320A, 311, 310, 328, 327,...		1-#8, 1-#8, 1-#8
1-#12, 1-#12, 1-#12		LTS CIRCULATION C350	20 A	1	21		0 VA			789 VA		**22**	**1**	**20 A**	Room 333, 332, 334, 335, 331, 330, 351,...		1-#12, 1-#12, 1-#12
					23						0 VA	24	1	20 A	LTS PENTHOUSE - EXISTING	--	--
1-#10, 1-#10, 1-#10		LTS Room 357, C350	20 A	1	25	1920 VA						26					
					27							28					
					29						0 VA	30	1	0 A	Spare	--	--
					31				0 VA			32	--	--	Space	--	--
--	--	Space	--	--	33		0 VA			0 VA		34	--	--	Space	--	--
--	--	Space	--	--	35			0 VA			0 VA	36	--	--	Space	--	--
--	--	Space	--	--	37	0 VA			0 VA			38	--	--	Space	--	--
--	--	Space	--	--	39		0 VA			0 VA		40	--	--	Space	--	--
--	--	Space	--	--	41			0 VA			0 VA	42	--	--	Space	--	--

Total Load:	9061 VA 3794 VA 3711 VA
Total Connected Load:	16579 VA
Total Conn. Current:	20 A
Total Est. Demand:	16579 VA
Total Est. Demand Current:	20 A

Notes:

Panel No: P3B

Mains Rating: 225 A
A.I.C. Rating: 10kA
Volts: 120/208 Wye
Service: 3Phase,4Wires

Supply From: T3
MCB Rating: 225 A
(EXISTING)

Location: LEVEL 3/ELECTRIC ROOM 353
Mounting: Surface
Mains Type:
Enclosure: Indoor

Notes:

Wire Size	Conduit Size	Load Name	Trip	Poles	CKT	ØA	ØB	ØC	ØA	ØB	ØC	CKT	Poles	Trip	Load Name	Conduit Size	Wire Size
1-#12, 1-#12, 1-#12		RECP WAITING 357	20 A	1	1	900 VA			720 VA			2	1	20 A	RECP CALL CENTER 313		1-#12, 1-#12, 1-#12
1-#10, 1-#10, 1-#10		RECP WAITING 357	20 A	1	3		1080 VA			720 VA		4	1	20 A	RECP CALL CENTER 313	3/4"	1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP ROOMERS 356	20 A	1	5			720 VA			1080 VA	6	1	20 A	RECP CALL CENTER 313	3/4"	1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP ROOMERS 356	20 A	1	7	720 VA			1080 VA			8	1	20 A	RECP BILLING 314		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP ROOMERS 356	20 A	1	9		720 VA			720 VA		10	1	20 A	RECP BILLING 314		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP ROOMERS 356	20 A	1	11			540 VA			720 VA	12	1	20 A	RECP BILLING 314		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP RECEPTION 337	**20 A**	**1**	**13**	540 VA			1080 VA			14	1	**20 A**	RECP SCHEDULING & IT/REC 315		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP RECEPTION 337	**20 A**	**1**	**15**		720 VA			720 VA		16	1	20 A	RECP SCHEDULING & IT/REC 315		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP RECEPTION 337	**20 A**	**1**	**17**			540 VA			720 VA	18	1	20 A	RECP SCHEDULING & IT/REC 315		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP RECEPTION 337	**20 A**	**1**	**19**	540 VA			180 VA			20	**1**	**20 A**	RECP TLT-S 316A		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP CONSULT / CONF 351	**20 A**	**1**	**21**		720 VA			540 VA		22	**1**	**20 A**	RECP CORRIDOR C310		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP SVCS-OFF 377	**20 A**	**1**	**23**			900 VA			540 VA	**24**	**1**	**20 A**	RECP CORRIDOR C310		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP SVCS-OFF 376	**20 A**	**1**	**25**	900 VA			420 VA			**26**	**1**	**20 A**	RECP - UC FRIDGE LG CONF 304		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP DATA 307A	**20 A**	**1**	**27**		360 VA			360 VA		**28**	**1**	**20 A**	RECP LG CONF 304		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP DATA 307A	**20 A**	**1**	**29**			360 VA			900 VA	**30**	**1**	**20 A**	RECP Room 304, C300		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP DATA 307A	**20 A**	**1**	**31**	360 VA			540 VA			**32**	**1**	**20 A**	RECP LG CONF 304		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PHLEB 354	**20 A**	**1**	**33**		540 VA			540 VA		**34**	**1**	**20 A**	RECP Room 305, 318, 303		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP ELECTRIC ROOM 353	**20 A**	**1**	**35**			1440 VA			180 VA	**36**	**1**	**20 A**	RECP MAIL 307		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP TEL. 352	**20 A**	**1**	**37**	360 VA			180 VA			**38**	**1**	**20 A**	RECP MAIL 307		1-#12, 1-#12, 1-#12
--	--	Spare	**20 A**	**1**	**39**		0 VA			0 VA		**40**	**1**	**20 A**	Spare	--	--
--	--	Spare	**20 A**	**1**	**41**			0 VA			0 VA	**42**	**1**	**20 A**	Spare	--	--

Total Load:	8520 VA 7740 VA 8640 VA
Total Connected Load:	24900 VA
Total Conn. Current:	69 A
Total Est. Demand:	17660 VA
Total Est. Demand Current:	49 A

Notes:

Panel No: P3A

Mains Rating: 225 A
A.I.C. Rating: 10kA
Volts: 120/208 Wye
Service: 3Phase,4Wires

Supply From: T3
MCB Rating: 225 A
(EXISTING)

Location: LEVEL 3/ELECTRIC ROOM 353
Mounting: Surface
Mains Type: MLO
Enclosure: Indoor

Notes:
FEED THROUGH LUGS

Wire Size	Conduit Size	Load Name	Trip	Poles	CKT	ØA	ØB	ØC	ØA	ØB	ØC	CKT	Poles	Trip	Load Name	Conduit Size	Wire Size
1-#12, 1-#12, 1-#12		RECP EXAM 338	20 A	1	1	720 VA			900 VA			2	1	20 A	RECP Room C330, 332, 336		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 339	20 A	1	3		720 VA			180 VA		4	1	20 A	RECP TLT-P 335		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 340	20 A	1	5			720 VA			360 VA	6	1	20 A	RECP MED SUPPLY 334		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFFICE-NP 341	20 A	1	7	540 VA			720 VA			8	1	20 A	RECP WORK 333		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFFICE-NP 341	20 A	1	9		720 VA			900 VA		10	1	20 A	RECP EXAM-SN 331		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFFICE-NP 341	20 A	1	11			540 VA			1080 VA	12	1	20 A	RECP Room 348, 347		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 342	20 A	1	13	720 VA			900 VA			14	1	20 A	RECP OPEN WORK 320		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 343	20 A	1	15		900 VA			900 VA		16	1	20 A	RECP OPEN WORK 320		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP EXAM 344	20 A	1	17			900 VA			900 VA	18	1	20 A	RECP OPEN WORK 320		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFFICE/ FUTURE EXAM 321	20 A	1	19	900 VA			900 VA			20	1	20 A	RECP OPEN WORK 320		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 322	20 A	1	21		900 VA			1080 VA		22	1	20 A	RECP OPEN WORK 320		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 323	20 A	1	23			900 VA			720 VA	24	1	20 A	RECP OPEN WORK 301		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 324	20 A	1	25	900 VA			360 VA			26	1	20 A	RECP PRINT STATION 302		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP PROVIDER 325	20 A	1	27		900 VA			900 VA		28	1	20 A	RECP OFF 310		1-#12, 1-#12, 1-#12
1-#10, 1-#10, 1-#10		RECP PROVIDER 326	20 A	1	29			900 VA			900 VA	30	1	20 A	RECP OFF 311		1-#12, 1-#12, 1-#12
1-#8, 1-#8, 1-#8		RECP OFF 327	20 A	1	31	1080 VA			900 VA			32	1	20 A	RECP OFF 312		1-#12, 1-#12, 1-#12
					33						1080 VA	34	1	20 A	RECP Room C310, C320, 320A		1-#8, 1-#8, 1-#8
1-#12, 1-#12, 1-#12		RECP OFF 328	20 A	1	35			900 VA			540 VA	36	1	20 A	RECP Room 306, 355, L300		1-#12, 1-#12, 1-#12
1-#12, 1-#12, 1-#12		RECP OFF 329	20 A	1	37	900 VA			360 VA			38	1	20 A	RECP TEL. 352		1-#12, 1-#12, 1-#12
--	--	Spare	20 A	1	39		0 VA					40					
--	--	Spare	20 A	1	41			0 VA			0 VA	42	1	0 A	Spare	--	--

Total Load:	10800 VA 9180 VA 9360 VA
Total Connected Load:	29340 VA
Total Conn. Current:	81 A
Total Est. Demand:	19670 VA
Total Est. Demand Current:	55 A

Notes:

LIGHTING FIXTURE SCHEDULES

Iden Tag	Manufacturer	Model	Description	Mounting	Color	Lamp Type	Voltage	Luminous Flux	Ballast Type	Total Watts	Type Comments
							277 V	1380 lm		100 VA	
A	METALUX	12EN-LD2-08-UNV-L835-CD1-U	1X2 RECESSED	RECESSED	WHITE	LED	277 V	1936 lm	0-10V LED DRIVER	11 VA	
A1	METALUX	22EN-LD2-19-UNV-L835-CD1-U	2X2 RECESSED	RECESSED	WHITE	LED	277 V	1936 lm	0-10V LED DRIVER	19 VA	
A1D	METALUX	22EN-LD2-19-UNV-L835-CD1-U - 1%	2X2 RECESSED	RECESSED	WHITE	LED	277 V	1967 lm	0-10V LED DRIVER 1% DIMMING	19 VA	
A1DE	METALUX	22EN-LD2-19-UNV-L835-CD1-U - 1%	2X2 RECESSED - EM FIXTURE	RECESSED	WHITE	LED	277 V	1936 lm	0-10V LED DRIVER 1% DIMMING	19 VA	
A1E	METALUX	22EN-LD2-19-UNV-L835-CD1-U	2X2 RECESSED - EM FIXTURE	RECESSED	WHITE	LED	277 V	1936 lm	0-10V LED DRIVER	19 VA	
A2	METALUX	22EN-LD2-25-UNV-L835-CD1-U	2X2 RECESSED	RECESSED	WHITE	LED	277 V	2537 lm	0-10V LED DRIVER	26 VA	
A2E	METALUX	22EN-LD2-25-UNV-L835-CD1-U	2X2 RECESSED - EM FIXTURE	RECESSED	WHITE	LED	277 V	2537 lm	0-10V LED DRIVER	26 VA	
A3	METALUX	22EN-LD2-30-UNV-L835-CD1-U	2X2 RECESSED	RECESSED	WHITE	LED	277 V	3002 lm	0-10V LED DRIVER	30 VA	
A3E	METALUX	22EN-LD2-30-UNV-L835-CD1-U	2X2 RECESSED- EM FIXTURE	RECESSED	WHITE	LED	277 V	3002 lm	0-10V LED DRIVER	30 VA	
A4	METALUX	22EN-LD2-34-UNV-L835-CD1-U	2X2 RECESSED	RECESSED	WHITE	LED	277 V	3424 lm	0-10V LED DRIVER	35 VA	
A5	METALUX	22EN-LD2-39-UNV-L835-CD1-U	2X2 RECESSED	RECESSED	WHITE	LED	277 V	3424 lm	0-10V LED DRIVER	35 VA	
B1	METALUX	24EN-LD2-30-UNV-L835-CD1-U	2X4 RECESSED	RECESSED	WHITE	LED	277 V	3040 lm	0-10V LED DRIVER	30 VA	
B2	METALUX	24EN-LD2-40-UNV-L835-CD1-U	2X4 RECESSED	RECESSED	WHITE	LED	277 V	3040 lm	0-10V LED DRIVER	30 VA	
B4	METALUX	24EN-LD2-54-UNV-L835-CD1-U	2X4 RECESSED	RECESSED	WHITE	LED	277 V	3040 lm	0-10V LED DRIVER	30 VA	
CV6	COLOR KINETICS	523-000090-94 912400133258	COVE LIGHT	SURFACE	WHITE	LED	277 V	167 lm	LED	2 VA	
CV12	COLOR KINETICS	523-000091-94 912400133274	COVE LIGHT	SURFACE	WHITE	LED	277 V	286 lm	LED	3 VA	
CV48	COLOR KINETICS	523-000092-94 912400133290	COVE LIGHT	SURFACE	WHITE	LED	277 V	900 lm	LED	10 VA	
D1	PORTFOLIO	LDSQ4A-09-D010TE-ESQ4A09-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	RECESSED	WHITE	LED	277 V	939 lm	0-10V LED DRIVER	14 VA	
D1E	PORTFOLIO	LDSQ4A-09-D010TE-ESQ4A09-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	RECESSED	WHITE	LED	277 V	939 lm	0-10V LED DRIVER	14 VA	
D2	PORTFOLIO	LDSQ4A-13-D010TE-ESQ4A13-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	RECESSED	WHITE	LED	277 V	1506 lm	0-10V LED DRIVER	22 VA	
D2E	PORTFOLIO	LDSQ4A-13-D010TE-ESQ4A13-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	RECESSED	WHITE	LED	277 V	1506 lm	0-10V LED DRIVER	22 VA	
D2W	PORTFOLIO	LDSQ4A-13-D010TE-ESQ4A13-835-4LSQLWW0-LI	4 IN SQUARE DOWNLIGHT	RECESSED	WHITE	LED	277 V	1506 lm	0-10V LED DRIVER	22 VA	
D3	PORTFOLIO	LDSQ4A-18-D010TE-ESQ4A18-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	CEILING	WHITE	LED	277 V	1233 lm	LED DRIVER	21 VA	
D3D	PORTFOLIO	LDSQ4A-18-DE010-ESQ4A18-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT - 1% DIM	RECESSED	WHITE	LED	277 V	2255 lm	0-10V LED DRIVER 1% DIMMING	32 VA	
D3E	PORTFOLIO	LDSQ4A-18-D010TE-ESQ4A18-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT	CEILING	WHITE	LED	277 V	1233 lm	LED DRIVER	21 VA	
D3WD	PORTFOLIO	LDSQ4A-18-DE010-ESQ4A18-835-4LSQLWW0-LI	4 IN SQUARE DOWNLIGHT - 1% DIM	RECESSED	WHITE	LED	277 V	2255 lm	0-10V LED DRIVER 1% DIMMING	32 VA	
D4	PORTFOLIO	LDSQ4A-28-D010TE-ESQ4A28-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT - 1% DIM	RECESSED	WHITE	LED	277 V	2771 lm	0-10V LED DRIVER	43 VA	
D4E	PORTFOLIO	LDSQ4A-28-D010TE-ESQ4A28-835-4LSQ1-LI	4 IN SQUARE DOWNLIGHT - 1% DIM	RECESSED	WHITE	LED	277 V	2771 lm	0-10V LED DRIVER	43 VA	
DM4D	FAIL-SAFE	FLD6A-30-DE010-FERM6A-30-4100 \ FSR6LM1-W	6 IN ROUND DOWNLIGHT SEAL 1%	RECESSED	WHITE	LED	277 V	2714 lm	0-10V LED DRIVER 1% DIMMING	46 VA	
EB	SURELITES	LEM4-SD	EMERGENCY LIGHT	WALL RECESSED	WHITE	LED	277 V	786 lm	LED	8 VA	EM. BATTERY
EB1	SURELITES	LEM4-SD- 120V	EMERGENCY LIGHT	WALL RECESSED	WHITE	LED	120 V	786 lm	LED	8 VA	EM. BATTERY
F5	NEO-RAY	S123-RDRP-LO-35-FRS-0060*-1-U-ED-1-W	Direct Recessed Perimeter	RECESSED	WHITE	LED	277 V	2125 lm	0-10V LED DRIVER	25 VA	S123, S124 and S125
F5.8	NEO-RAY	S123-RDRP-LO-35-GRID-0068*-1-U-ED-1-W	Direct Recessed Perimeter	RECESSED	WHITE	LED	277 V	2550 lm	0-10V LED DRIVER	30 VA	S123, S124 and S125
F6	NEO-RAY	S123-RDRP-LO-35-GRID-0071*-1-U-ED-1-W	Direct Recessed Perimeter	RECESSED	WHITE	LED	277 V	2975 lm	0-10V LED DRIVER	35 VA	S123, S124 and S125
F6.9	NEO-RAY	S123-RDRP-LO-35-GRID-0081*-1-U-ED-1-W	Direct Recessed Perimeter	RECESSED	WHITE	LED	277 V	3570 lm	0-10V LED DRIVER	42 VA	S123, S124 and S125
F8	NEO-RAY	S123-RDRP-LO-35-GRID-0143*-1-U-ED-1-W	Direct Recessed Perimeter	RECESSED	WHITE	LED	277 V	4760 lm	0-10V LED DRIVER	56 VA	S123, S124 and S125
GE	METALUX	4SWLED-LD4-4400HL-UNV-EL14-L835-CD1-S/PD2-U	STAIR WELLS	WALL @ EXISTING	WHITE	LED	277 V	4398 lm	0-10V LED DRIVER	39 VA	W/ EM. BATTERY
GS	METALUX	2SNLED-LD4-18SL-LN-UNV-L835-CD1-U	2' ABOVE DOOR STORAGE	WALL @ ABOVE DOOR	WHITE	LED	277 V	1785 lm	LED	17 VA	
GS1	METALUX	4SNLED-LD4-18SL-LN-UNV-L835-CD1-U	4' ABOVE DOOR STORAGE	WALL @ ABOVE DOOR	WHITE	LED	277 V	2032 lm	LED	18 VA	
H	NEO-RAY	123-DR-1-35-FSR-0047-1-U-DD-T-1-W	Direct Recessed	RECESSED	WHITE	LED	277 V	2380 lm	0-10V LED DRIVER	28 VA	
HA	NEO-RAY	123-DR-1-35-