

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01				Account ID: 9186		
Group	Loop	Address	Messages		Event	CID
Detector	1	001	SMOKE 4TH FL	PROCEDURE RM 450	Active	111101001
					Disable	157001001
					Maintenance Alert	139301001
					Test	161401001
					Trouble	137301001
Detector	1	002	SMOKE 4TH FL	PROCEDURE RM 459	Active	111101002
					Disable	157001002
					Maintenance Alert	139301002
					Test	161401002
					Trouble	137301002
Detector	1	003	SMOKE 4TH FL	PROCEDURE RM 458	Active	111101003
					Disable	157001003
					Maintenance Alert	139301003
					Test	161401003
					Trouble	137301003
Detector	1	004	SMOKE 4TH FL	PROCEDURE RM 457	Active	111101004
					Disable	157001004
					Maintenance Alert	139301004
					Test	161401004
					Trouble	137301004
Detector	1	005	SMOKE 4TH FL	PROCEDURE RM 463	Active	111101005
					Disable	157001005
					Maintenance Alert	139301005
					Test	161401005
					Trouble	137301005
Detector	1	006	SMOKE 1ST FL	DATA CLOSET 158	Active	111101006
					Disable	157001006
					Maintenance Alert	139301006
					Test	161401006
					Trouble	137301006
Detector	1	007	SMOKE 4TH FL	I/S OFFICE 401	Active	111101007
					Disable	157001007
					Maintenance Alert	139301007
					Test	161401007
					Trouble	137301007
Detector	1	008	SMOKE 4TH FL	I/S WAITING RM	Active	111101008
					Disable	157001008
					Maintenance Alert	139301008
					Test	161401008
					Trouble	137301008
Detector	1	009	SMOKE 2ND FLOOR	ELEVATOR LOBBY LEFT	Active	111101009
					Disable	157001009

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
				Maintenance Alert	139301009
				Test	161401009
				Trouble	137301009
Detector	1	010	SMOKE 4TH FL I/S INFUSION RM 403	Active	111101010
				Disable	157001010
				Maintenance Alert	139301010
				Test	161401010
				Trouble	137301010
Detector	1	011	SMOKE 4TH FL TELE DATA RM 416	Active	111101011
				Disable	157001011
				Maintenance Alert	139301011
				Test	161401011
				Trouble	137301011
Detector	1	012	SMOKE 4TH FL ELECTRIC RM 440	Active	111101012
				Disable	157001012
				Maintenance Alert	139301012
				Test	161401012
				Trouble	137301012
Detector	1	013	DUCT SMOKE 4TH FL CORR. C450	Active	120001013
				Disable	157001013
				Maintenance Alert	139301013
				Test	161401013
				Trouble	137301013
Detector	1	014	DUCT SMOKE 4TH FL CLEAN SUPPLY 453	Active	120001014
				Disable	157001014
				Maintenance Alert	139301014
				Test	161401014
				Trouble	137301014
Detector	1	015	DUCT SMOKE 4TH FL SCOPE STORAGE 461	Active	120001015
				Disable	157001015
				Maintenance Alert	139301015
				Test	161401015
				Trouble	137301015
Detector	1	016	DUCT SMOKE 4TH FL O/S PATHOLOGY 400A	Active	120001016
				Disable	157001016
				Maintenance Alert	139301016
				Test	161401016
				Trouble	137301016
Detector	1	017	SMOKE 4TH FL PROCEDURE RM 451	Active	111101017
				Disable	157001017
				Maintenance Alert	139301017
				Test	161401017

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
				Trouble	137301017
Detector	1	018	SMOKE 4TH FL PREP RECOVERY 484	Active	111101018
				Disable	157001018
				Maintenance Alert	139301018
				Test	161401018
				Trouble	137301018
Detector	1	019	SMOKE 4TH FL I/S STAFF LOUNGE 402	Active	111101019
				Disable	157001019
				Maintenance Alert	139301019
				Test	161401019
				Trouble	137301019
Detector	1	020	SMOKE 4TH FL TOILET 406	Active	111101020
				Disable	157001020
				Maintenance Alert	139301020
				Test	161401020
				Trouble	137301020
Detector	1	021	SMOKE 4TH FL OFFICE 404	Active	111101021
				Disable	157001021
				Maintenance Alert	139301021
				Test	161401021
				Trouble	137301021
Detector	1	022	SMOKE 4TH FL ELEVATOR LOBBY LEFT	Active	111101022
				Disable	157001022
				Maintenance Alert	139301022
				Test	161401022
				Trouble	137301022
Detector	1	023	SMOKE 3RD FL ELEVATOR LOBBY	Active	111101023
				Disable	157001023
				Maintenance Alert	139301023
				Test	161401023
				Trouble	137301023
Detector	1	024	SMOKE 3RD FL DATA CLOSET 352	Active	111101024
				Disable	157001024
				Maintenance Alert	139301024
				Test	161401024
				Trouble	137301024
Detector	1	025	SMOKE 3RD FL ELECTRIC RM 353	Active	111101025
				Disable	157001025
				Maintenance Alert	139301025
				Test	161401025
				Trouble	137301025

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
Detector	1	026	HEAT 3RD FL ELECTRIC RM 353	Active	111401026
				Disable	157001026
				Maintenance Alert	139301026
				Test	161401026
				Trouble	137301026
Detector	1	027	HEAT 3RD FL EMERGENCY ELEC ROOM	Active	111401027
				Disable	157001027
				Maintenance Alert	139301027
				Test	161401027
				Trouble	137301027
Detector	1	028	SMOKE 3RD FL DATA CLOSET 307A	Active	111101028
				Disable	157001028
				Maintenance Alert	139301028
				Test	161401028
				Trouble	137301028
Detector	1	029	SMOKE 1ST FL ELEVATOR LOBBY RIGHT	Active	111101029
				Disable	157001029
				Maintenance Alert	139301029
				Test	161401029
				Trouble	137301029
Detector	1	030	SMOKE 1ST FL ENTRANCE LOBBY	Active	111101030
				Disable	157001030
				Maintenance Alert	139301030
				Test	161401030
				Trouble	137301030
Detector	1	031	SMOKE 4TH FL ELEVATOR LOBBY RIGHT	Active	111101031
				Disable	157001031
				Maintenance Alert	139301031
				Test	161401031
				Trouble	137301031
Detector	1	032	SMOKE 1ST FL ELEV MACHINE RM 125A	Active	111101032
				Disable	157001032
				Maintenance Alert	139301032
				Test	161401032
				Trouble	137301032
Detector	1	033	HEAT 1ST FL ELEV MACHINE RM 125A	Active	111401033
				Disable	157001033
				Maintenance Alert	139301033
				Test	161401033
				Trouble	137301033
Detector	1	034	SMOKE 1ST FL EMERGENCY ELEC 122B	Active	111101034
				Disable	157001034

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
				Maintenance Alert	139301034	
				Test	161401034	
				Trouble	137301034	
Detector	1	036	SMOKE 1ST FL ELECTRIC ROOM	Active	111101036	
				Disable	157001036	
				Maintenance Alert	139301036	
				Test	161401036	
				Trouble	137301036	
Detector	1	037	SMOKE 4TH FL I/S TOILET 483	Active	111101037	
				Disable	157001037	
				Maintenance Alert	139301037	
				Test	161401037	
				Trouble	137301037	
Detector	1	038	SMOKE 4TH FL HALL O/S INFUSION	Active	111101038	
				Disable	157001038	
				Maintenance Alert	139301038	
				Test	161401038	
				Trouble	137301038	
Detector	1	039	DUCT SMOKE HVAC4 FL1 STERILIZER RM	Active	120001039	
				Disable	157001039	
				Maintenance Alert	139301039	
				Test	161401039	
				Trouble	137301039	
Detector	1	040	SMOKE 1ST FL HALLWAY BY RECEPTION	Active	111101040	
				Disable	157001040	
				Maintenance Alert	139301040	
				Test	161401040	
				Trouble	137301040	
Detector	1	041	SMOKE 2ND FL ELECTRIC ROOM	Active	111101041	
				Disable	157001041	
				Maintenance Alert	139301041	
				Test	161401041	
				Trouble	137301041	
Detector	1	042	SMOKE 2ND FL SECURITY RM	Active	111101042	
				Disable	157001042	
				Maintenance Alert	139301042	
				Test	161401042	
				Trouble	137301042	
Detector	1	043	SMOKE 1ST FL ELEVATOR LOBBY LEFT	Active	111101043	
				Disable	157001043	
				Maintenance Alert	139301043	
				Test	161401043	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01				Account ID: 9186		(continued)	
Group	Loop	Address	Messages	Event	CID		
				Trouble	137301043		
Detector	1	044	SMOKE 2ND FL ELEVATOR LOBBY RIGHT	Active	111101044		
				Disable	157001044		
				Maintenance Alert	139301044		
				Test	161401044		
				Trouble	137301044		
Detector	1	045	SMOKE 2ND FL TELE/ DATA CLOSET	Active	111101045		
				Disable	157001045		
				Maintenance Alert	139301045		
				Test	161401045		
				Trouble	137301045		
Detector	1	046	SMOKE 1ST FL CORR BY LAZER EXAM 120	Active	111101046		
				Disable	157001046		
				Maintenance Alert	139301046		
				Test	161401046		
				Trouble	137301046		
Detector	1	047	SMOKE 1ST FL BY DOOR TO ELEVATOR LOBBY	Active	111101047		
				Disable	157001047		
				Maintenance Alert	139301047		
				Test	161401047		
				Trouble	137301047		
Detector	1	048	SMOKE 1ST FL IN PRE OP BY RM 108.4	Active	111101048		
				Disable	157001048		
				Maintenance Alert	139301048		
				Test	161401048		
				Trouble	137301048		
Module	1	126	3RD FL BOOSTER 2 TROUBLE	Active	120001126		
				Disable	157001126		
				Maintenance Alert	139301126		
				Test	161401126		
				Trouble	137301126		
Module	1	127	3RD FL BOOSTER 1 TROUBLE	Active	120001127		
				Disable	157001127		
				Maintenance Alert	139301127		
				Test	161401127		
				Trouble	137301127		
Module	1	128	4TH FL BOOSTER TROUBLE	Active	120001128		
				Disable	157001128		
				Maintenance Alert	139301128		
				Test	161401128		
				Trouble	137301128		

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
Module	1	129	SMOKE DAMPER RELAY I/S WAITING RM 412	Active	137301129
				Disable	157001129
				Maintenance Alert	139301129
				Test	161401129
				Trouble	137301129
Module	1	130	SMOKE DAMPER RELAY STAFF RM 402 LEFT	Active	137301130
				Disable	157001130
				Maintenance Alert	139301130
				Test	161401130
				Trouble	137301130
Module	1	131	SMOKE DAMPER RELAY STAFF RM 402 RIGHT	Active	137301131
				Disable	157001131
				Maintenance Alert	139301131
				Test	161401131
				Trouble	137301131
Module	1	132	SMOKE DAMPER RELAY I/S INFUSION DR RGHT	Active	137301132
				Disable	157001132
				Maintenance Alert	139301132
				Test	161401132
				Trouble	137301132
Module	1	133	SMOKE DAMPER RELAY I/S INFUSION DR LEFT	Active	137301133
				Disable	157001133
				Maintenance Alert	139301133
				Test	161401133
				Trouble	137301133
Module	1	134	SMOKE DAMPER RELAY TLT 406 RIGHT SIDE	Active	137301134
				Disable	157001134
				Maintenance Alert	139301134
				Test	161401134
				Trouble	137301134
Module	1	135	SMOKE DAMPER RELAY TLT 406 LEFT SIDE	Active	137301135
				Disable	157001135
				Maintenance Alert	139301135
				Test	161401135
				Trouble	137301135
Module	1	136	SMOKE DAMPER RELAY I/S OFFICE 404	Active	137301136
				Disable	157001136
				Maintenance Alert	139301136
				Test	161401136
				Trouble	137301136
Module	1	137	PULL STATION 4TH FL AT STAIR 1	Active	111501137
				Disable	157001137

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
				Maintenance Alert	139301137
				Test	161401137
				Trouble	137301137
Module	1	138	PULL STATION 4TH FL AT SATIR 2	Active	111501138
				Disable	157001138
				Maintenance Alert	139301138
				Test	161401138
				Trouble	137301138
Module	1	139	4TH FL SHUTDOWN CLEAN SUPPLY 453	Active	137301139
				Disable	157001139
				Maintenance Alert	139301139
				Test	161401139
				Trouble	137301139
Module	1	140	4TH FL SHUTDOWN SCOPE STORAGE 461	Active	137301140
				Disable	157001140
				Maintenance Alert	139301140
				Test	161401140
				Trouble	137301140
Module	1	141	4TH FL SHUTDOWN OUTSIDE 400A	Active	137301141
				Disable	157001141
				Maintenance Alert	139301141
				Test	161401141
				Trouble	137301141
Module	1	142	PULL STATION 3RD FL STAIR TOWER 2	Active	111501142
				Disable	157001142
				Maintenance Alert	139301142
				Test	161401142
				Trouble	137301142
Module	1	143	PULL STATION 1ST FL MARGINAL ENTR	Active	111501143
				Disable	157001143
				Maintenance Alert	139301143
				Test	161401143
				Trouble	137301143
Module	1	144	PULL STATION 1ST FL VEST 122A	Active	111501144
				Disable	157001144
				Maintenance Alert	139301144
				Test	161401144
				Trouble	137301144
Module	1	145	PULL STATION CORR. 140 REAR EXIT	Active	111501145
				Disable	157001145
				Maintenance Alert	139301145
				Test	161401145

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01				Account ID: 9186		(continued)	
Group	Loop	Address	Messages	Event	CID		
				Trouble	137301145		
Module	1	146	PULL STATION 1ST FL VESTIBULE 145	Active	111501146		
				Disable	157001146		
				Maintenance Alert	139301146		
				Test	161401146		
				Trouble	137301146		
Module	1	147	1ST FL SPRINKLER WATERFLOW	Active	111001147		
				Disable	157001147		
				Maintenance Alert	139301147		
				Test	161401147		
				Trouble	137301147		
Module	1	148	1ST FL SPRINKLER TAMPER	Active	120001148		
				Disable	157001148		
				Maintenance Alert	139301148		
				Test	161401148		
				Trouble	137301148		
Module	1	149	1ST FL ELEV SHUT TRIP POWER LOSS	Active	120001149		
				Disable	157001149		
				Maintenance Alert	139301149		
				Test	161401149		
				Trouble	137301149		
Module	1	150	1ST FL ELEVATOR PRIMARY RECALL	Active	137301150		
				Disable	157001150		
				Maintenance Alert	139301150		
				Test	161401150		
				Trouble	137301150		
Module	1	151	1ST FL ELEVATOR ALTERNATE RECALL	Active	137301151		
				Disable	157001151		
				Maintenance Alert	139301151		
				Test	161401151		
				Trouble	137301151		
Module	1	152	1ST FL ELEVATOR SHUT TRIP RELAY	Active	137301152		
				Disable	157001152		
				Maintenance Alert	139301152		
				Test	161401152		
				Trouble	137301152		
Module	1	153	1ST FL ELEVATOR SPRINKLER TAMPER	Active	120001153		
				Disable	157001153		
				Maintenance Alert	139301153		
				Test	161401153		
				Trouble	137301153		

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
Module	1	154	Loop 1 Device 154 SPARE	Active	120001154
				Disable	157001154
				Maintenance Alert	139301154
				Test	161401154
				Trouble	137301154
Module	1	155	IST FL ELEVATOR HAT RELAY	Active	137301155
				Disable	157001155
				Maintenance Alert	139301155
				Test	161401155
				Trouble	137301155
Module	1	156	PULL STATION 3RD FL OUTSIDE STAIR 1	Active	111501156
				Disable	157001156
				Maintenance Alert	139301156
				Test	161401156
				Trouble	137301156
Module	1	157	4TH FLOOR SHUTDOWN RELAY COR 450	Active	137301157
				Disable	157001157
				Maintenance Alert	139301157
				Test	161401157
				Trouble	137301157
Module	1	158	RELAY SECURITY RM FL1	Active	137301158
				Disable	157001158
				Maintenance Alert	139301158
				Test	161401158
				Trouble	137301158
Module	1	159	DOOR HOLDER RELAY 1ST FL STAIR 2	Active	137301159
				Disable	157001159
				Maintenance Alert	139301159
				Test	161401159
				Trouble	137301159
Module	1	160	RELAY FL1 DAMPER RELAY1 HALL BY RM119	Active	137301160
				Disable	157001160
				Maintenance Alert	139301160
				Test	161401160
				Trouble	137301160
Module	1	161	RELAY FL1 DAMPER RELAY2 HALL BY RM119	Active	137301161
				Disable	157001161
				Maintenance Alert	139301161
				Test	161401161
				Trouble	137301161
Module	1	162	RELAY FL1 DAMPER RELAY3 HALL BY RM119	Active	137301162
				Disable	157001162

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:01 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
				Maintenance Alert	139301162	
				Test	161401162	
				Trouble	137301162	
Module	1	163	RELAY FL1 DAMPER RELY1 HALL BY RM122B	Active	137301163	
				Disable	157001163	
				Maintenance Alert	139301163	
				Test	161401163	
				Trouble	137301163	
Module	1	164	RELAY FL1 DAMPER RLY5 HALL BY RM108.4	Active	137301164	
				Disable	157001164	
				Maintenance Alert	139301164	
				Test	161401164	
				Trouble	137301164	
Module	1	165	RELAY FL1 DAMPER RLY6 HALL100/HALL112	Active	137301165	
				Disable	157001165	
				Maintenance Alert	139301165	
				Test	161401165	
				Trouble	137301165	
Module	1	166	HVAC4 FL1 SHUTDOWN RELAY STERILIZER RM	Active	137301166	
				Disable	157001166	
				Maintenance Alert	139301166	
				Test	161401166	
				Trouble	137301166	
Module	1	167	RELAY FL4 STAIR1 ELEC RM FAN OFF	Active	137301167	
				Disable	157001167	
				Maintenance Alert	139301167	
				Test	161401167	
				Trouble	137301167	
Module	1	168	2ND FLOOR LEFT BOOSTER TRBL	Active	120001168	
				Disable	157001168	
				Maintenance Alert	139301168	
				Test	161401168	
				Trouble	137301168	
Module	1	169	2ND FLOOR RIGHT BOOSTER TRBL	Active	120001169	
				Disable	157001169	
				Maintenance Alert	139301169	
				Test	161401169	
				Trouble	137301169	
Module	1	170	PULL STATION 2ND FL STAIR 2 EXIT	Active	111501170	
				Disable	157001170	
				Maintenance Alert	139301170	
				Test	161401170	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
				Trouble	137301170	
Module	1	172	PULL STATION 2ND FL TOP OF STAIR 1	Active	111501172	
				Disable	157001172	
				Maintenance Alert	139301172	
				Test	161401172	
				Trouble	137301172	
Zone		001	Zone 1	Active	111000001	
				Trouble	137300001	
				Disable	157000001	
				Maintenance Alert	139300001	
				Test	161400001	
Zone		002	Zone 2	Active	111000002	
				Trouble	137300002	
				Disable	157000002	
				Maintenance Alert	139300002	
				Test	161400002	
Zone		003	Zone 3	Active	111000003	
				Trouble	137300003	
				Disable	157000003	
				Maintenance Alert	139300003	
				Test	161400003	
Zone		004	Zone 4	Active	111000004	
				Trouble	137300004	
				Disable	157000004	
				Maintenance Alert	139300004	
				Test	161400004	
Zone		005	Zone 5	Active	111000005	
				Trouble	137300005	
				Disable	157000005	
				Maintenance Alert	139300005	
				Test	161400005	
Zone		006	Zone 6	Active	111000006	
				Trouble	137300006	
				Disable	157000006	
				Maintenance Alert	139300006	
				Test	161400006	
Zone		007	Zone 7	Active	111000007	
				Trouble	137300007	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186	(continued)
Group	Loop	Address	Messages	Event	CID
				Disable	157000007
				Maintenance Alert	139300007
				Test	161400007
Zone		008	Zone 8	Active	111000008
				Trouble	137300008
				Disable	157000008
				Maintenance Alert	139300008
				Test	161400008
Zone		009	Zone 9	Active	111000009
				Trouble	137300009
				Disable	157000009
				Maintenance Alert	139300009
				Test	161400009
Zone		010	Zone 10	Active	111000010
				Trouble	137300010
				Disable	157000010
				Maintenance Alert	139300010
				Test	161400010
Zone		011	Zone 11	Active	111000011
				Trouble	137300011
				Disable	157000011
				Maintenance Alert	139300011
				Test	161400011
Zone		012	Zone 12	Active	111000012
				Trouble	137300012
				Disable	157000012
				Maintenance Alert	139300012
				Test	161400012
Zone		013	Zone 13	Active	111000013
				Trouble	137300013
				Disable	157000013
				Maintenance Alert	139300013
				Test	161400013
Zone		014	Zone 14	Active	111000014
				Trouble	137300014
				Disable	157000014
				Maintenance Alert	139300014
				Test	161400014

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
Zone		015	Zone 15	Active	111000015	
				Trouble	137300015	
				Disable	157000015	
				Maintenance Alert	139300015	
				Test	161400015	
Zone		016	Zone 16	Active	111000016	
				Trouble	137300016	
				Disable	157000016	
				Maintenance Alert	139300016	
				Test	161400016	
Zone		017	Zone 17	Active	111000017	
				Trouble	137300017	
				Disable	157000017	
				Maintenance Alert	139300017	
				Test	161400017	
Zone		018	Zone 18	Active	111000018	
				Trouble	137300018	
				Disable	157000018	
				Maintenance Alert	139300018	
				Test	161400018	
Zone		019	Zone 19	Active	111000019	
				Trouble	137300019	
				Disable	157000019	
				Maintenance Alert	139300019	
				Test	161400019	
Zone		020	Zone 20	Active	111000020	
				Trouble	137300020	
				Disable	157000020	
				Maintenance Alert	139300020	
				Test	161400020	
Zone		021	Zone 21	Active	111000021	
				Trouble	137300021	
				Disable	157000021	
				Maintenance Alert	139300021	
				Test	161400021	
Zone		022	Zone 22	Active	111000022	
				Trouble	137300022	
				Disable	157000022	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
				Maintenance Alert	139300022	
				Test	161400022	
Zone		023	Zone 23	Active	111000023	
				Trouble	137300023	
				Disable	157000023	
				Maintenance Alert	139300023	
				Test	161400023	
Zone		024	Zone 24	Active	111000024	
				Trouble	137300024	
				Disable	157000024	
				Maintenance Alert	139300024	
				Test	161400024	
Zone		025	Zone 25	Active	111000025	
				Trouble	137300025	
				Disable	157000025	
				Maintenance Alert	139300025	
				Test	161400025	
Zone		026	Zone 26	Active	111000026	
				Trouble	137300026	
				Disable	157000026	
				Maintenance Alert	139300026	
				Test	161400026	
Zone		027	Zone 27	Active	111000027	
				Trouble	137300027	
				Disable	157000027	
				Maintenance Alert	139300027	
				Test	161400027	
Zone		028	Zone 28	Active	111000028	
				Trouble	137300028	
				Disable	157000028	
				Maintenance Alert	139300028	
				Test	161400028	
Zone		029	Zone 29	Active	111000029	
				Trouble	137300029	
				Disable	157000029	
				Maintenance Alert	139300029	
				Test	161400029	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
Zone		030	Zone 30	Active	111000030	
				Trouble	137300030	
				Disable	157000030	
				Maintenance Alert	139300030	
				Test	161400030	
Zone		031	Zone 31	Active	111000031	
				Trouble	137300031	
				Disable	157000031	
				Maintenance Alert	139300031	
				Test	161400031	
Zone		032	Zone 32	Active	111000032	
				Trouble	137300032	
				Disable	157000032	
				Maintenance Alert	139300032	
				Test	161400032	
Correlation		001	Correlation 1	Disable	157000000	
Correlation		002	Correlation 2	Disable	157000000	
Correlation		003	Correlation 3	Disable	157000000	
Correlation		004	Correlation 4	Disable	157000000	
Correlation		005	Correlation 5	Disable	157000000	
Correlation		006	Correlation 6	Disable	157000000	
Correlation		007	Correlation 7	Disable	157000000	
Correlation		008	Correlation 8	Disable	157000000	
Correlation		009	Correlation 9	Disable	157000000	
Correlation		010	Correlation 10	Disable	157000000	
Correlation		011	Correlation 11	Disable	157000000	
Correlation		012	Correlation 12	Disable	157000000	
Correlation		013	Correlation 13	Disable	157000000	
Correlation		014	Correlation 14	Disable	157000000	
Correlation		015	Correlation 15	Disable	157000000	
Correlation		016	Correlation 16	Disable	157000000	
Events		002	Loop 1 Fault	Trouble	133100000	
Events		003	Loop 1 Map Fault	Trouble	133100000	
Events		004	Loop 1 Interface Card Fault	Trouble	133300000	
Events		005	Loop 1 Unconfigured Alarm	Active	111000000	

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01

Account ID: 9186

(continued)

Group	Loop	Address	Messages	Event	CID
Events		022	Program Mode	Trouble	162700000
Events		023	Reset	Active	130500000
Events		028	Walk Test	Trouble	160700000
Events		030	Clear History	Trouble	162100000
Events		031	User Set Time	Trouble	162500000
Events		032	User Set Date	Trouble	162500000
Events		033	Common Disable	Trouble	150000000
Events		035	Ground Fault	Trouble	131000000
Events		036	Battery Charger	Trouble	130900000
Events		037	Battery Low	Trouble	130200000
Events		038	Battery Placement	Trouble	131100000
Events		040	Auxiliary Power 1	Trouble	131200000
Events		041	Auxiliary Power 2	Trouble	131200000
Events		042	System AC Power	Trouble	130100000
Events		043	Common Alarm	Active	111000000
Events		044	Common Supervisory	Active	120000000
Events		046	Common Trouble for Telco	Trouble	137300000
Events		3030	Firmware Download Aborted	Trouble	100000000
Events		3031	Firmware Download Failed	Trouble	100000000
Events		050	Internal panel Fault	Trouble	130700000
Events		051	Dialer Disable Remote Disconnect	Trouble	155100000
Events		052	Dialer Telephone Line 1 Fault	Trouble	135100000
Events		053	Dialer Telephone Line 2 Fault	Trouble	135200000
Events		054	Dialer Delivery Failure	Trouble	135400000
Events		055	Dialer Normal Test	Trouble	160200000
Events		056	Dialer Abnormal Test	Trouble	160800000
Events		058	Net Receiver 1 Communication Trouble	Trouble	135400000
Events		059	Net Receiver 2 Communication Trouble	Trouble	135400000
Events		060	Net Receiver 3 Communication Trouble	Trouble	135400000
Events		061	Net Receiver 4 Communication Trouble	Trouble	135400000
Events		062	Net Receiver 5 Communication Trouble	Trouble	135400000
Events		063	Net Receiver 6 Communication Trouble	Trouble	135400000
Events		064	Net Receiver 7 Communication Trouble	Trouble	135400000
Events		065	Net Receiver 8 Communication Trouble	Trouble	135400000

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

Telco Account 01				Account ID: 9186		(continued)
Group	Loop	Address	Messages	Event	CID	
Events		066	Net Receiver 1 Configuration Trouble	Trouble	135400000	
Events		067	Net Receiver 2 Configuration Trouble	Trouble	135400000	
Events		068	Net Receiver 3 Configuration Trouble	Trouble	135400000	
Events		069	Net Receiver 4 Configuration Trouble	Trouble	135400000	
Events		070	Net Receiver 5 Configuration Trouble	Trouble	135400000	
Events		071	Net Receiver 6 Configuration Trouble	Trouble	135400000	
Events		072	Net Receiver 7 Configuration Trouble	Trouble	135400000	
Events		073	Net Receiver 8 Configuration Trouble	Trouble	135400000	
Events		074	IP Gateway Trouble	Trouble	135400000	
Events		079	NAC 1 Fault	Disable	152100000	
				Test	160000000	
				Trouble	132100000	
Events		080	NAC 2 Fault	Disable	152200000	
				Test	160000000	
				Trouble	132200000	
Events		083	Printer Fault	Trouble	133600000	
Events		084	Annunciator 1 Fault	Trouble	133400000	
Events		085	Annunciator 2 Fault	Trouble	133400000	
Events		086	Annunciator 3 Fault	Trouble	133400000	
Events		087	Annunciator 4 Fault	Trouble	133400000	
Events		088	Annunciator 5 Fault	Trouble	133400000	
Events		089	Annunciator 6 Fault	Trouble	133400000	
Events		090	Annunciator 7 Fault	Trouble	133400000	
Events		091	Annunciator 8 Fault	Trouble	133400000	

IP Account 1				FFFF	
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 2				FFFF	
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

SAS Dialer Report

Project : 161_MARGINAL_WAY_PORTLAND

Panel : PANEL1

Date : 7/24/2017 11:18:02 AM

IP Account 3		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 4		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 5		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 6		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 7		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					

IP Account 8		FFFF			
Group	Loop	Address	Messages	Event	CID
This IP Account is disabled					