



. . . Fire Protection by Computer Design

Eastern Fire Protection
170 Kitty Hawk Ave.
P.O. Box 1390
Auburn, Maine, 04211
207-784-1507

Job Name : PORTLAND GASTRO. FOURTH FLOOR REMOTE AREA
Drawing : 1 OF 2
Location : 161 MARGINAL WAY, PORTLAND, MAINE
Remote Area : ONE
Contract : 5458-16
Data File : PORTLAND GASTRO FOURTH FLOOR PROOF.WXF

HYDRAULIC CALCULATIONS
for

Project name: PORTLAND GASTRO. FOURTH FLOOR REMOTE AREA

Location: 161 MARGINAL WAY, PORTLAND, MAINE

Drawing no: 1 OF 2

Date: 5/26/13

Design

Remote area number: ONE

Remote area location: FOURTH FLOOR

Occupancy classification: LIGHT

Density: .10 - Gpm/SqFt

Area of application: 971 - SqFt

Coverage per sprinkler: 148 - SqFt

Type of sprinklers calculated: 1/2" K=5.6 RELIABE F1FR CHROME PENDENT

No. of sprinklers calculated: 10

In-rack demand: - GPM

Hose streams: 100 - GPM

Total water required (including hose streams): 276.9 - GPM @ 87.14 - Psi

Type of system: WET

Volume of dry or preaction system: - Gal

Water supply information

Date: 6/22/2006

Location: HYDRANT LOCATED ON MARGINAL WAY

Source: PORTLAND WATER DISTRICT

Name of contractor: Eastern Fire Protection

Address: 170 Kitty Hawk Ave. / P.O. Box 1390 / Auburn, Maine, 04211

Phone number: 207-784-1507

Name of designer: WAF

Authority having jurisdiction: STATE FIRE MARSHAL

Notes: (Include peaking information or gridded systems here.)

NOTE: REMOTE AREA MODIFIED PER NFPA 13 SECTION 11.2.3.2.3.1


Water Supply Curve C

Eastern Fire Protection
PORTLAND GASTRO. FOURTH FLOOR REMOTE AREA

Page 2
Date

City Water Supply:
C1 - Static Pressure : 112
C2 - Residual Pressure: 108
C2 - Residual Flow : 2846

Demand:
D1 - Elevation : 20.642
D2 - System Flow : 176.993
D2 - System Pressure : 87.144
Hose (Demand) : 100
D3 - System Demand : 276.993
Safety Margin : 24.802



Fittings Used Summary

Eastern Fire Protection
 PORTLAND GASTRO. FOURTH FLOOR REMOTE AREA

Page 3
 Date

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90° Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90° Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
TEST	112.0	108	2846.0	111.946	276.99	87.144

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
D1	0.0	5.6	7.0	14.82	
50	147.66	4.06	13.84	15.08	K=K @ L1
51	147.66	4.06	13.35	14.82	K=K @ L1
52	147.66	4.06	14.42	15.4	K=K @ L1
53	147.66		14.72		
54	147.66	4.06	23.43	19.63	K=K @ L1
55	147.66	4.06	26.45	20.86	K=K @ L1
56	148.33	4.06	17.69	17.05	K=K @ L1
57	148.33	4.06	18.66	17.51	K=K @ L1
58	147.66		34.38		
59	147.66	4.06	18.93	17.64	K=K @ L1
60	147.66		20.04		
61	147.66	4.06	21.07	18.62	K=K @ L1
62	147.66	4.06	25.26	20.38	K=K @ L1
63	147.66		30.59		
AA	147.66		51.87		
BB	147.66		52.13		
D	147.66		52.26		
TOR	109.0		73.44		
B1	109.0		78.39		
BASE	101.0		86.55		
TEST	100.0		87.14	100.0	

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
D1 to L1	0 0	5.60	14.82 14.82	1 1.049	E T	2.0 5.0 0.0	78.000 7.000 85.000	120 0.0747	7.000 0.0 6.350			Vel = 5.50
L1			0.0 14.82						13.350		K Factor = 4.06	
50 to 53	147.660 147.660	4.06	15.08 15.08	1 1.049	T	5.0 0.0 0.0	6.500 5.000 11.500	120 0.0772	13.837 0.0 0.888		K = K @ L1	Vel = 5.60
53			0.0 15.08						14.725		K Factor = 3.93	
51 to 52	147.660 147.660	4.06	14.82 14.82	1 1.049	E	2.0 0.0 0.0	12.370 2.000 14.370	120 0.0747	13.350 0.0 1.073		K = K @ L1	Vel = 5.50
52 to 53	147.660 147.660	4.06	15.40 30.22	1 1.049		0.0 0.0 0.0	1.080 0.0 1.080	120 0.2796	14.423 0.0 0.302		K = K @ L1	Vel = 11.22
53 to 54	147.660 147.660		15.08 45.3	1 1.049	E	2.0 0.0 0.0	12.740 2.000 14.740	120 0.5906	14.725 0.0 8.705			Vel = 16.82
54 to 55	147.660 147.660	4.06	19.63 64.93	1.25 1.38		0.0 0.0 0.0	10.000 0.0 10.000	120 0.3023	23.430 0.0 3.023		K = K @ L1	Vel = 13.93
55 to 58	147.660 147.660	4.06	20.86 85.79	1.25 1.38	2E	6.0 0.0 0.0	9.670 6.000 15.670	120 0.5061	26.453 0.0 7.931		K = K @ L1	Vel = 18.40
58			0.0 85.79						34.384		K Factor = 14.63	
56 to 57	148.330 148.330	4.06	17.05 17.05	1 1.049		0.0 0.0 0.0	10.000 0.0 10.000	120 0.0969	17.687 0.0 0.969		K = K @ L1	Vel = 6.33
57 to 63	148.330 147.660	4.06	17.52 34.57	1 1.049	4E T	8.0 5.0 0.0	19.500 13.000 32.500	120 0.3581	18.656 0.290 11.639		K = K @ L1	Vel = 12.83
63			0.0 34.57						30.585		K Factor = 6.25	
58 to AA	147.660 147.660		85.79 85.79	1.25 1.38	T	6.0 0.0 0.0	28.540 6.000 34.540	120 0.5061	34.384 0.0 17.481			Vel = 18.40
AA			0.0 85.79						51.865		K Factor = 11.91	
59 to 60	147.660 147.660	4.06	17.64 17.64	1 1.049	T	5.0 0.0 0.0	5.790 5.000 10.790	120 0.1032	18.928 0.0 1.113		K = K @ L1	Vel = 6.55
60 to 61	147.660 147.660		0.0 17.64	1 1.049		0.0 0.0 0.0	10.000 0.0 10.000	120 0.1032	20.041 0.0 1.032			Vel = 6.55

Final Calculations - Hazen-Williams

Eastern Fire Protection
 PORTLAND GASTRO. FOURTH FLOOR REMOTE AREA

Page 6
 Date

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
61 to 62	147.660 147.660	4.06	18.62 36.26	1 1.049		0.0 0.0	10.710 0.0	120 0.3911	21.073 0.0 4.189		K = K @ L1 Vel = 13.46	
62 to 63	147.660 147.660	4.06	20.38 56.64	1.25 1.38	E T	3.0 6.0	13.670 9.000	120	25.262 0.0 5.323		K = K @ L1 Vel = 12.15	
63 to BB	147.660 147.660		34.57 91.21	1.25 1.38	2E T	6.0 6.0	26.000 12.000	120	30.585 0.0 21.542		Vel = 19.56	
BB			0.0 91.21						52.127		K Factor = 12.63	
AA to BB	147.660 147.660		85.79 85.79	2.5 2.635		0.0 0.0	12.080 0.0	120	51.865 0.0 0.262		Vel = 5.05	
BB to D	147.660 147.660		91.20 176.99	2.5 2.635		0.0 0.0	1.620 0.0	120	52.127 0.0 0.135		Vel = 10.41	
D to TOR	147.660 109		0.0 176.99	3 3.26	5I J	33.599 17.471	100.000 51.070	120	52.262 16.744 4.437		Vel = 6.80	
TOR to B1	109 109		0.0 176.99	3 3.26	B S	13.44 21.503	100.000 68.542	120	73.443 0.0 4.951		Vel = 6.80	
B1 to BASE	109 101		0.0 176.99	4 4.26	I Zcb	9.217 0.0	8.000 9.217	120	78.394 8.020 0.138		* * Fixed Loss = 4.555 Vel = 3.98	
BASE to TEST	101 100		0.0 176.99	6 6.16	L G T	12.911 4.304 43.037	100.000 60.252 160.252	140	86.552 0.433 0.159		Vel = 1.91	
TEST			100.00 276.99						87.144		Qa = 100.00 K Factor = 29.67	