



**LEGEND:**

RISER DIAG SYM	NFPA SYMBOL*	DESCRIPTION	CATALOG #
[FACP]	[FACP]	Fire Alarm Control Panel (existing)	EST 10500RD
[FAA]	[FAA]	Remote Annunciator (existing)	RLCD-CR
[F]	[P]	Addressable Manual Station	SIGA-278
[?]	[?]	Addressable Smoke Detector w/ Base	SIGA2-PS SIGA-SB
[?]	[?]	Addressable Heat Detector	SIGA2-HFS SIGA-SB
[?]	[?]	Addressable Duct Smoke Detector w/ Remote Test Switch	SIGA-SD, SD-TRK, SD-xx
[CT-1]	[M]	Addressable Single/Dual Monitor Module	SIGA-CT112
[CCIS]		Addressable Synchronization Module	SIGA-CCIS
[X]	[X]	Strobe Unit (Adjustable Candela)	G1RF-VM
[X]	[X]	Horn/Strobe Unit (Adjustable Candela)	G1RF-HVDM

\* NFPA 720 (2009)  
Tables: 6.5, 6.7.1, 6.7.2, & 6.7.3

DWG NAME: **161 Marginal Way  
Portland, ME  
First Floor  
Fire Alarm Floor Plans**  
DWG No. FA-102

**R.B. Allen  
Co., Inc.**  
P.O. BOX 770  
131 LAKE ST  
N.O. HAMPTON, NH 03892  
1-800-258-7284

EDWARDS SYSTEM TECHNOLOGY

JOB NAME: **161 Marginal Way  
Portland, Maine  
Fire Alarm Floor Plans**

REV.	DESCRIPTION	DATE	BY	TRD.
0	Original Issue	8/16	KMB	TRD
				DRWN: RWV/D

SCALE: 1/8" = 1'0"

PO No. 161 Marginal Way  
Portland, Maine  
First Floor  
Fire Alarm Floor Plans  
DWG No. FA-102