



LEGEND:

| RISER DIAG SYM | NFPA SYMBOL* | DESCRIPTION | CATALOG # |
|----------------|--------------|---|---------------------------|
| [FACP] | [FACP] | Fire Alarm Control Panel (existing) | EST 10500RD |
| [FAA] | [FAA] | Remote Annunciator (existing) | RLCD-CR |
| [F] | [P] | Addressable Manual Station | SIGA-278 |
| [S] | [S] | Addressable Smoke Detector w/ Base | SIGA2-PS SIGA-SB |
| [H] | [H] | Addressable Heat Detector | SIGA2-HFS SIGA-SB |
| [A] | [A] | Addressable Duct Smoke Detector w/ Remote Test Switch | SIGA-SD, SD-TRK, SD-xx |
| [CT1/2] | [M] | Addressable Single/Dual Monitor Module | SIGA-CT1/2 |
| [CC1S] | [CC1S] | Addressable Synchronization Module | SIGA-CC1S |
| [X] | [X] | Strobe Unit (Adjustable Candela) | G1RF-VM |
| [H] | [H] | Horn/Strobe Unit (Adjustable Candela) | G1RF-HDVM |

*NFPA 170 (2009)
Tables: 6.5, 6.7-1, 6.7.2, & 6.7.3

DWG NAME: **161 Marginal Way
Portland, ME
Second Floor
Fire Alarm Floor Plans**

DWG No: FA-103

**R.B. Allen
Co., Inc.**
P.O. BOX 170
131 LAKE ST
NO. HAMPTON, NH 03862
1-800-258-7284

EDWARDS SYSTEM TECHNOLOGY

JOB NAME: **161 Marginal Way
Portland, Maine
Fire Alarm Floor Plans**

SCALE: 1/8" = 1'0"

| REV. | DESCRIPTION | DATE | BY | CHKD | TRD |
|------|----------------|------|-----|------|-----|
| 0 | Original Issue | 8/16 | KMB | | |
| | | | | | |

PO No. _____

161 Marginal Way
Portland, Maine
Second Floor
Fire Alarm Floor Plans
DWG No. FA-103