



LEGEND:

RISER DIAG SYM	NFPA SYMBOL*	DESCRIPTION	CATALOG #
FACP	FACP	Fire Alarm Control Panel (existing)	EST IO500RD
FAA	FAA	Remote Annunciator (existing)	RLCD-CR
F	P	Addressable Manual Station	SIGA-278
?	?	Addressable Smoke Detector w/ Base	SIGA2-PS SIGA-SB
?	?	Addressable Heat Detector	SIGA2-HFS SIGA-SB
?	?	Addressable Duct Smoke Detector w/ Remote Test Switch	SIGA-SD, SD-TRK, SD-xx
CT1	CT1	Addressable Single/Dual Monitor Module	SIGA-CT1/2
CC1S	CC1S	Addressable Synchronization Module	SIGA-CC1S
⊗	⊗	Strobe Unit (Adjustable Candela)	G1RF-VM
⊗	⊗	Horn/Strobe Unit (Adjustable Candela)	G1RF-HDVM

*NFPA 72 (2009)
Tables: 6.5, 6.7.1, 6.7.2, & 6.7.3

DWG NAME: **161 Marginal Way
Portland, ME
Third Floor
Fire Alarm Floor Plans**
DWG No.: FA-104



JOB NAME: **161 Marginal Way
Portland, Maine
Fire Alarm Floor Plans**

REV.	DATE	DESCRIPTION	8/16	KMB	TRD	DRWN:	RWW/D:
0		Original Issue					

SCALE: 1/8" = 1'0"
PO No. _____
161 Marginal Way
Portland, Maine
Third Floor
Fire Alarm Floor Plans
DWG No. FA-104