

**iO500RD Addressable Fire Alarm System
161 Marginal Way
Portland, Maine**

System Narrative

In the event of an alarm from an actuated device, the following shall occur:

(Devices reporting an alarm: Manual Station, Smoke Detector, Heat Detector)

- 1) Notify Portland Fire Department via Central Monitoring Station.
- 2) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 3) Sound a Code 3 Temporal on all Horn Circuits
- 4) Flash all strobe appliance circuits in a synchronized manner

In the event of a supervisory condition from an actuated device, the following shall occur:

(Devices reporting an alarm: Duct Smoke Detector)

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel
- 2) Notify Central Monitoring Station

In the event of a system trouble report, the following shall occur:

- 1) Annunciate audibly, visually, and in plain English the active initiating device at the fire alarm control panel.
- 2) Notify Central Monitoring Station