

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 7

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre Alarm	Follows Latched Follow CO	Operation AltOperation
1	1	PS Smoke	Standard 3973796123	SMOKE 4TH FL PROCEDURE RM 450	Least Least	N/A N/A	None None	None No	N/A N/A
1	2	PS Smoke	Standard 3973783468	SMOKE 4TH FL PROCEDURE RM 459	Least Least	N/A N/A	None None	None No	N/A N/A
1	3	PS Smoke	Standard 3973783574	SMOKE 4TH FL PROCEDURE RM 458	Least Least	N/A N/A	None None	None No	N/A N/A
1	4	PS Smoke	Standard 3973796116	SMOKE 4TH FL PROCEDURE RM 457	Least Least	N/A N/A	None None	None No	N/A N/A
1	5	PS Smoke	Standard 3973783550	SMOKE 4TH FL PROCEDURE RM 463	Least Least	N/A N/A	None None	None No	N/A N/A
1	6	PS Smoke	Standard 3973783796	SMOKE 1ST FL DATA CLOSET 158	Least Least	N/A N/A	None None	None No	N/A N/A
1	7	PS Smoke	Standard 3973783307	SMOKE 4TH FL I/S OFFICE 401	Least Least	N/A N/A	None None	None No	N/A N/A
1	8	PS Smoke	Standard 3973794891	SMOKE 4TH FL I/S WAITING RM	Least Least	N/A N/A	None None	None No	N/A N/A
1	9	PS Smoke	Standard 3973781648	SMOKE 2ND FLOOR ELEVATOR LOBBY LEFT	Least Least	N/A N/A	None None	None No	N/A N/A

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 8

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors (continued)									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre	Follows Latched Follow CO	Operation Alt Operation
1	10	PS Smoke	Standard 3973781716	SMOKE 4TH FL I/S INFUSION RM 403	Least Least	N/A N/A	None None	None No	N/A N/A
1	11	PS Smoke	Standard 3973783314	SMOKE 4TH FL TELE DATA RM 416	Least Least	N/A N/A	None None	None No	N/A N/A
1	12	PS Smoke	Standard 3973795218	SMOKE 4TH FL ELECTRIC RM 440	Least Least	N/A N/A	None None	None No	N/A N/A
1	13	SD Duct Supervisory Latching	Relay 3968330837	DUCT SMOKE 4TH FL CORR. C450	N/A N/A	N/A N/A	None None	Head No	N/A N/A
1	14	SD Duct Supervisory Latching	Relay 3968330424	DUCT SMOKE 4TH FL CLEAN SUPPLY 453	N/A N/A	N/A N/A	None None	Head No	N/A N/A
1	15	SD Duct Supervisory Latching	Relay 3968330578	DUCT SMOKE 4TH FL SCOPE STORAGE 461	N/A N/A	N/A N/A	None None	Head No	N/A N/A
1	16	SD Duct Supervisory Latching	Relay 3968331360	DUCT SMOKE 4TH FL O/S PATHOLOGY 400A	N/A N/A	N/A N/A	None None	Head No	N/A N/A
1	17	PS Smoke	Standard 3973795188	SMOKE 4TH FL PROCEDURE RM 451	Least Least	N/A N/A	None None	None No	N/A N/A
1	18	PS Smoke	Standard 3973783246	SMOKE 4TH FL PREP RECOVERY 484	Least Least	N/A N/A	None None	None No	N/A N/A

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 9

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors (continued)									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre	Follows Latched Follow CO	Operation Alt Operation
1	19	PS Smoke	Standard 3973795102	SMOKE 4TH FL I/S STAFF LOUNGE 402	Least Least	N/A N/A	None None	None No	N/A N/A
1	20	PS Smoke	Standard 3973783505	SMOKE 4TH FL TOILET 406	Least Least	N/A N/A	None None	None No	N/A N/A
1	21	PS Smoke	Standard 3973794884	SMOKE 4TH FL OFFICE 404	Least Least	N/A N/A	None None	None No	N/A N/A
1	22	PS Smoke	Standard 3973783772	SMOKE 4TH FL ELEVATOR LOBBY LEFT	Least Least	N/A N/A	None None	None No	N/A N/A
1	23	PS Smoke	Standard 3973795584	SMOKE 3RD FL ELEVATOR LOBBY	Least Least	N/A N/A	None None	None No	N/A N/A
1	24	PS Smoke	Standard 3973790022	SMOKE 3RD FL DATA CLOSET 352	Least Least	N/A N/A	None None	None No	N/A N/A
1	25	PS Smoke	Standard 3973782065	SMOKE 3RD FL ELECTRIC RM 353	Least Least	N/A N/A	None None	None No	N/A N/A
1	26	HFS Heat	Standard 3688120541	HEAT 3RD FL ELECTRIC RM 353	N/A N/A	N/A N/A	None None	None No	N/A N/A
1	27	HFS Heat	Standard 3688119316	HEAT 3RD FL EMERGENCY ELEC ROOM	N/A N/A	N/A N/A	None None	None No	N/A N/A

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 10

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors (continued)									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre	Follows Latched Follow CO	Operation Alt Operation
1	28	PS Smoke	Standard 3973781754	SMOKE 3RD FL DATA CLOSET 307A	Least Least	N/A N/A	None None	None No	N/A N/A
1	29	PS Smoke	Standard 3973782041	SMOKE 1ST FL ELEVATOR LOBBY RIGHT	Least Least	N/A N/A	None None	None No	N/A N/A
1	30	PS Smoke	Standard 3973782539	SMOKE 1ST FL ENTRANCE LOBBY	Least Least	N/A N/A	None None	None No	N/A N/A
1	31	PS Smoke	Standard 3973952444	SMOKE 4TH FL ELEVATOR LOBBY RIGHT	Least Least	N/A N/A	None None	None No	N/A N/A
1	32	PS Smoke	Standard 3973951201	SMOKE 1ST FL ELEV MACHINE RM 125A	Least Least	N/A N/A	None None	None No	N/A N/A
1	33	HFS Heat	Standard 3688120046	HEAT 1ST FL ELEV MACHINE RM 125A	N/A N/A	N/A N/A	None None	None No	N/A N/A
1	34	PS Smoke	Standard 3973781556	SMOKE 1ST FL EMERGENCY ELEC 122B	Least Least	N/A N/A	None None	None No	N/A N/A
1	36	PS Smoke	Standard 3973795119	SMOKE 1ST FL ELECTRIC ROOM	Least Least	N/A N/A	None None	None No	N/A N/A
1	37	PS Smoke	Standard 3973795348	SMOKE 4TH FL I/S TOILET 483	Least Least	N/A N/A	None None	None No	N/A N/A

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 11

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors (continued)									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre	Follows Latched Follow CO	Operation Alt Operation
1	38	PS Smoke Verified	Standard 3973782447	SMOKE 4TH FL HALL O/S INFUSION	Least Least	Yes Yes	None None	None No	N/A N/A
1	39	SD Duct Supervisory Latching	Relay 3968330967	DUCT SMOKE HVAC4 FL1 STERILIZER RM	N/A N/A	N/A N/A	None None	Head No	N/A N/A
1	40	PS Smoke	Standard 3973783444	SMOKE 1ST FL HALLWAY BY RECEPTION	Least Least	N/A N/A	None None	None No	N/A N/A
1	41	PS Smoke	Standard 3973783420	SMOKE 2ND FL ELECTRIC ROOM	Least Least	N/A N/A	None None	None No	N/A N/A
1	42	PS Smoke	Standard 3973928807	SMOKE 2ND FL SECURITY RM	Least Least	N/A N/A	None None	None No	N/A N/A
1	43	PS Smoke	Standard 3973795256	SMOKE 1ST FL ELEVATOR LOBBY LEFT	Least Least	N/A N/A	None None	None No	N/A N/A
1	44	PS Smoke	Standard 3973782126	SMOKE 2ND FL ELEVATOR LOBBY RIGHT	Least Least	N/A N/A	None None	None No	N/A N/A
1	45	PS Smoke	Standard 3973782805	SMOKE 2ND FL TELE/ DATA CLOSET	Least Least	N/A N/A	None None	None No	N/A N/A
1	46	PS Smoke	Standard 3973885711	SMOKE 1ST FL CORR BY LAZER EXAM 120	Least Least	N/A N/A	None None	None No	N/A N/A

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 12

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Detectors (continued)									
Loop	Address	Model Device Type	Base Type Serial Number	Messages	Sensitivity Alt. Sens.	Verification Alt. Verify	Pre Alarm Alt. Pre	Follows Latched Follow CO	Operation Alt Operation
1	47	PS Smoke	Standard 3973781679	SMOKE 1ST FL BY DOOR TO ELEVATOR LOBBY	Least Least	N/A N/A	None None	None No	N/A N/A
1	48	PS Smoke	Standard 3973782423	SMOKE 1ST FL IN PRE OP BY RM 108.4	Least Least	N/A N/A	None None	None No	N/A N/A

Modules									
Loop	Address	Model	Device Type	Serial Number	Messages	Verify	Alt. Vfy		
1	126	CT1	Supervisory Non-Latching	4808966636	3RD FL BOOSTER 2	TROUBLE	N/A	N/A	
1	127	CT1	Supervisory Non-Latching	4808966278	3RD FL BOOSTER 1	TROUBLE	N/A	N/A	
1	128	CT1	Supervisory Non-Latching	4808968241	4TH FL BOOSTER	TROUBLE	N/A	N/A	
1	129	CR	Relay Non-Silenceable	5207159308	SMOKE DAMPER RELAY	I/S WAITING RM 412	N/A	N/A	
1	130	CR	Relay Non-Silenceable	5207147183	SMOKE DAMPER RELAY	STAFF RM 402 LEFT	N/A	N/A	
1	131	CR	Relay Non-Silenceable	5207159285	SMOKE DAMPER RELAY	STAFF RM 402 RIGHT	N/A	N/A	
1	132	CR	Relay Non-Silenceable	5207130048	SMOKE DAMPER RELAY	I/S INFUSION DR RGHT	N/A	N/A	
1	133	CR	Relay Non-Silenceable	5207170907	SMOKE DAMPER RELAY	I/S INFUSION DR LEFT	N/A	N/A	
1	134	CR	Relay Non-Silenceable	5207085232	SMOKE DAMPER RELAY	TLT 406 RIGHT SIDE	N/A	N/A	
1	135	CR	Relay Non-Silenceable	5207096627	SMOKE DAMPER RELAY	TLT 406 LEFT SIDE	N/A	N/A	
1	136	CR	Relay Non-Silenceable	5207118510	SMOKE DAMPER RELAY	I/S OFFICE 404	N/A	N/A	
1	137	278	Pull Station	4892080140	PULL STATION	4TH FL AT STAIR 1	N/A	N/A	
1	138	278	Pull Station	4892052307	PULL STATION	4TH FL AT SATIR 2	N/A	N/A	
1	139	CR	Relay Non-Silenceable	5207090731	4TH FL SHUTDOWN	CLEAN SUPPLY 453	N/A	N/A	
1	140	CR	Relay Non-Silenceable	5207116059	4TH FL SHUTDOWN	SCOPE STORAGE 461	N/A	N/A	
1	141	CR	Relay Non-Silenceable	5207159520	4TH FL SHUTDOWN	OUTSIDE 400A	N/A	N/A	
1	142	278	Pull Station	4892106697	PULL STATION	3RD FL STAIR TOWER 2	N/A	N/A	

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 13

Panel : PANEL1

Date : 7/24/2017 11:18:59 AM

Modules (continued)									
Loop	Address	Model	Device Type	Serial Number	Messages		Verify	Alt. Vfy	
1	143	278	Pull Station	4892113435	PULL STATION	1ST FL MARGINAL ENTR	N/A	N/A	
1	144	278	Pull Station	4892105973	PULL STATION	1ST FL VEST 122A	N/A	N/A	
1	145	278	Pull Station	4892109308	PULL STATION	CORR. 140 REAR EXIT	N/A	N/A	
1	146	278	Pull Station	4892104495	PULL STATION 1ST FL	VESTIBULE 145	N/A	N/A	
1	147	CT1	Alarm	4808966186	1ST FL	SPRINKLER WATERFLOW	N/A	N/A	
1	148	CT1	Supervisory Non-Latching	4808968005	1ST FL	SPRINKLER TAMPER	N/A	N/A	
1	149	CT1	Supervisory Non-Latching	4808966827	1ST FL ELEV SHUT	TRIP POWER LOSS	N/A	N/A	
1	150	CR	Relay Non-Silenceable	5207156734	1ST FL ELEVATOR	PRIMARY RECALL	N/A	N/A	
1	151	CR	Relay Non-Silenceable	5207159490	1ST FL ELEVATOR	ALTERNATE RECALL	N/A	N/A	
1	152	CR	Relay Non-Silenceable	5207159483	1ST FL ELEVATOR	SHUT TRIP RELAY	N/A	N/A	
1	153	CT2	Supervisory Non-Latching	4908766440	1ST FL ELEVATOR	SPRINKLER TAMPER	N/A	N/A	
1	154	CT2	Supervisory Non-Latching	4908766457	Loop 1 Device 154	SPARE	N/A	N/A	
1	155	CR	Relay Non-Silenceable	5207505358	1ST FL ELEVATOR	HAT RELAY	N/A	N/A	
1	156	278	Pull Station	4892057210	PULL STATION 3RD FL	OUTSIDE STAIR 1	N/A	N/A	
1	157	CR	Relay Non-Silenceable	5207130079	4TH FLOOR SHUTDOWN	RELAY COR 450	N/A	N/A	
1	158	CR	Relay Non-Silenceable	5205137858	RELAY SECURITY	RM FL1	N/A	N/A	
1	159	CR	Relay Non-Silenceable	5207766780	DOOR HOLDER RELAY	1ST FL STAIR 2	N/A	N/A	
1	160	CR	Relay Non-Silenceable	5208520541	RELAY FL1 DAMPER	RELAY1 HALL BY RM119	N/A	N/A	
1	161	CR	Relay Non-Silenceable	5208525645	RELAY FL1 DAMPER	RELAY2 HALL BY RM119	N/A	N/A	
1	162	CR	Relay Non-Silenceable	5208530366	RELAY FL1 DAMPER	RELAY3 HALL BY RM119	N/A	N/A	
1	163	CR	Relay Non-Silenceable	5208519996	RELAY FL1 DAMPER	RELY1 HALL BY RM122B	N/A	N/A	
1	164	CR	Relay Non-Silenceable	5208522514	RELAY FL1 DAMPER	RLY5 HALL BY RM108.4	N/A	N/A	
1	165	CR	Relay Non-Silenceable	5207351917	RELAY FL1 DAMPER	RLY6 HALL100/HALL112	N/A	N/A	
1	166	CR	Relay Non-Silenceable	5208505876	HVAC4 FL1 SHUTDOWN	RELAY STERILIZER RM	N/A	N/A	
1	167	CR	Relay Non-Silenceable	5208519286	RELAY FL4 STAIR1	ELEC RM FAN OFF	N/A	N/A	
1	168	CT2	Supervisory Non-Latching	4908769588	2ND FLOOR	LEFT BOOSTER TRBL	N/A	N/A	
1	169	CT2	Supervisory Non-Latching	4908769595	2ND FLOOR	RIGHT BOOSTER TRBL	N/A	N/A	
1	170	278	Pull Station	4894064704	PULL STATION 2ND FL	STAIR 2 EXIT	N/A	N/A	

# SAS Panel Configuration

Project : 161\_MARGINAL\_WAY\_PORTLAND

Page: 14

Panel : PANEL1

Date : 7/24/2017 11:19:00 AM

Modules <span style="float: right;">(continued)</span>										
Loop	Address	Model	Device Type	Serial Number	Messages	Verify	Alt. Vfy			
1	172	278	Pull Station	4892129122	PULL STATION 2ND FL	TOP OF STAIR 1	N/A	N/A		

User Key 1		
Operation		
Function	Disable	
Correlation	Description	Type
13	Correlation 13	Members

User Key 2		
Operation		
Function	Disable	
Correlation	Description	Type
14	Correlation 14	Members

Correlation 1		Activation Count: 1	Delay: 0	InSuiteSignalSilence: False	
<u>Input</u>					
Group	Description	Loop	Address	Type	Messages
Detector	PS	1	1	Smoke	SMOKE 4TH FL PROCEDURE RM 450
Detector	PS	1	2	Smoke	SMOKE 4TH FL PROCEDURE RM 459
Detector	PS	1	3	Smoke	SMOKE 4TH FL PROCEDURE RM 458
Detector	PS	1	4	Smoke	SMOKE 4TH FL PROCEDURE RM 457