

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

161 MARGINAL WAY LLC

Located at

161 Marginal Way

PERMIT ID: 2016-02759

ISSUE DATE: 11/23/2016

CBL: 025 B001001

has permission to **Installation of one wall sign for Maine Eye Center**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

N/A

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
Offices

Building Inspections

Fire Department

PERMIT ID: 2016-02759

Located at: 161 Marginal Way

CBL: 025 B001001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Commercial
Site VISIT

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02759	Date Applied For: 10/21/2016	CBL: 025 B001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Professional Offices		Proposed Project Description: Installation of one wall sign for Maine Eye Center		
<p>Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 11/23/2016</p> <p>Note: B-7 zone, multitenant (Maine Eye is on 1st & 2nd floors) Ok to Issue: <input checked="" type="checkbox"/></p> <p>Sign not to exceed 5% of façade area Sign facing Marginal Way - façade area 6,710 sf = 335 sf of signage allowed, proposing 116 sf sign - OK Not currently seeking permit for sign facing Franklin Art. Waiver for individually-lit letter signs - granted by Planning.</p> <p>Conditions:</p> <p>1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.</p>				
<p>Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Laurie Leader Approval Date: 11/23/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <p>1) Signage and Awning Installation to comply with Chapters 16 (Structural Loads), 31 (Materials) & 32 (ROW Height & Encroachments) of the IBC 2009 building code.</p> <p>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.</p> <p>3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.</p>				
<p>Dept: Planning Status: Approved Pending Appeal Reviewer: Shukria Wiar Approval Date: 11/18/2016</p> <p>Note: Ok to Issue: <input checked="" type="checkbox"/></p> <p>Conditions:</p> <p>1) This permit is only for the building signs on the front façade at Marginal Way.</p> <p>2) Only the letters shall be internally illuminated and not the logo.</p>				